



EUROPEAN
COMMISSION

Brussels, XXX
[...] (2025) XXX draft

ANNEXES 1 to 8

ANNEXES

to the

COMMISSION REGULATION

setting ecodesign requirements for space heaters, combination heaters, temperature controls, solar devices, shower water heat recovery devices and packages of those products, amending and repealing Commission Regulation (EU) 813/2013 and repealing Council Directive 92/42/EEC

ANNEX I

Definitions applicable for Annexes II to VII

1. GENERIC DEFINITIONS

- (1) ‘declared values’ means the stated, calculated or measured values provided in the technical documentation by the manufacturer, importer or authorised representative;
- (2) ‘equivalent model’ means a model placed on the market with the same technical parameters set out in Annex II, as another model placed on the market or put into service by the same manufacturer;
- (3) ‘model identifier’ means the code, usually alphanumeric, which distinguishes a model from other models with the same brand or trade mark in the product database set under Regulation (EU) 2017/1369 ⁽¹⁾;

2. DEFINITIONS RELATED TO HEATERS

- (4) ‘conversion coefficient’ (CC) means the default coefficient referred to in Article 31(3) of Directive (EU) 2023/1791 of the European Parliament and of the Council ⁽²⁾ in the version in force on 10 October 2023;
- (5) ‘standby mode’ means a condition where the heater is connected to the mains power source and provides only the following functions, which may persist for an indefinite time:
 - (a) reactivation function, or reactivation function and only an indication of enabled reactivation function;
 - (b) reactivation function through a connection to a network (‘network standby’);
 - (c) information or status display;
- (6) ‘active mode’ means a condition corresponding to the hours with a heating or cooling load for the enclosed space and activated heating or cooling function; for heat-pump heater, this condition may involve cycling of the heat-pump heater to reach or maintain a required indoor air temperature;
- (7) ‘network’ means a communication infrastructure as intended under Commission Regulation (EU) 2023/826 ⁽³⁾, Article 2 point (9);
- (8) ‘reactivation function’ means a function that via a remote switch, a remote control, an internal sensor or timer provides a switch from standby mode to another mode, including active mode, providing additional functions;

⁽¹⁾ Regulation (EU) 2017/1369 of the European Parliament and of the Council of 4 July 2017 setting a framework for energy labelling and repealing Directive 2010/30/EU (OJ L 198, 28.7.2017, p. 1; ELI: <http://data.europa.eu/eli/reg/2017/1369/oj>).

⁽²⁾ Directive (EU) 2023/1791 of the European Parliament and of the Council of 13 September 2023 on energy efficiency and amending Regulation (EU) 2023/955. (OJ L 231, 20.9.2023, p. 1, ELI: <http://data.europa.eu/eli/dir/2023/1791/oj>).

⁽³⁾ Commission Regulation (EU) 2023/826 of 17 April 2023 laying down ecodesign requirements for off mode, standby mode, and networked standby energy consumption of electrical and electronic household and office equipment pursuant to Directive 2009/125/EC of the European Parliament and of the Council and repealing Commission Regulations (EC) No 1275/2008 and (EC) No 107/2009 C/2023/2448 OJ L 103, 18.4.2023, p. 29. ELI: <http://data.europa.eu/eli/reg/2023/826/oj>).

- (9) 'standby mode power consumption' (P_{SB}) means the electric power consumption of a heater in standby mode, including network standby, expressed in kW;
- (10) 'climate conditions' means solar radiations during the heating season, or the temperature conditions during the heating season or during the cooling season, as expressed by the frequency, in hours, of the outdoor temperature bin values, rounded to the nearest integer, as provided for in Annex III Table 4;
- (11) 'average climate conditions' in heating mode' means the climate conditions characteristic for the city of Strasbourg;
- (12) 'colder climate conditions in heating mode' means the climate conditions characteristic for the city of Helsinki;
- (13) 'warmer climate conditions' in heating mode' means the climate conditions characteristic for the cities of Athens;
- (14) 'average climate conditions' in cooling mode means a weighted average distribution based on several European capital cities;
- (15) 'gross calorific value' (GCV) means the total amount of heat released by a unit quantity of fuel when it is burned completely with oxygen and when the products of combustion are returned to ambient temperature; this quantity includes the condensation heat of any water vapour contained in the fuel and of the water vapour formed by the combustion of any hydrogen contained in the fuel;
- (16) 'control correction factor' ($F(1)$) means a correction factor for a basic temperature control, subtracting 3 percentage points from the seasonal space-heating energy-efficiency;
- (17) 'auxiliary electricity correction factor' ($F(2)$) means the factor equal to the electric auxiliary consumption of the heater as a fraction of the total annual energy consumption of the heater, expressed in percentage points;
- (18) 'auxiliary electricity consumption' means the annual amount of electricity consumed by the heater components such as the fan, the valves, and the heating elements required for the heat generator designated operation, but not the circulation pump, expressed in kWh/a;
- (19) 'seasonal space heating energy efficiency' ($\eta_{s,h}$) means the ratio between the space-heating demand supplied by a heater and the annual energy consumption required to meet this demand, expressed in %;
- (20) 'seasonal space heating energy efficiency in active mode' (η_{son}) means the seasonal space-heating energy-efficiency during the hours with a space-heating load, whereby the heating function of the heater is activated, possibly involving on/off cycling of the heater to reach or maintain a required instantaneous heat load;
- (21) 'heat output' (P) means the heat produced by a heater which is transmitted to the water-based heat distribution system, expressed in kW;
- (22) 'water-based heat distribution system' means a system using water as a heat-transfer medium to distribute generated heat to heat emitters for the space heating of buildings, or parts thereof;

- (23) ‘building automation and control system’ means a building automation and control system as defined in Article 2, point (7), of Directive (EU) 2024/1275 ⁽⁴⁾;
- (24) ‘spare part’ means a separate part that can replace a part with the same or similar function in a product;
- (25) ‘proprietary tool’ means a tool that is not available for purchase by the general public or for which any applicable patents are not available to licence under fair, reasonable and non-discriminatory terms
- (26) ‘energy smart appliance’ means a product whose supplier is a signatory of the Code of Conduct on energy management related interoperability of energy smart appliances, and which is compliant with this Code of Conduct;
- (27) ‘global warming potential’ (GWP) means the ratio characterizing the relative climate radiative forcing impact of a refrigerant fluid over a reference period in relation to the climate radiative forcing impact of CO₂, as intended in Regulation (EU) No 2024/573 ⁽⁵⁾ of the European Parliament and of the Council, in Article 3 point (1);
- (28) ‘fluorinated green-house gases’ means the fluorinated green-house gases in scope of Regulation (EU) 2024/573 of the European Parliament and of the Council ⁽⁶⁾;

3. DEFINITIONS RELATED TO FUEL AND ELECTRIC BOILER HEATERS, AND COGENERATION HEATERS

- (29) ‘B1 boiler heater’ means a fuel boiler heater incorporating a draught diverter, intended to be connected to a natural draught flue that evacuates the residues of combustion to the outside of the room containing the fuel boiler heater, and drawing the combustion air directly from the room;
- (30) ‘condensing boiler heater’ means a fuel boiler heater in which, under normal operating conditions and at given operating water temperatures, the water vapour in the combustion products is partially condensed, in order to make use of the latent heat of this water vapour for heating purposes;
- (31) ‘space-heating efficiency’ (η) means:
 - (a) for fuel boiler heaters: the ratio of the heat output in kW and the heat input in kW in terms of the GCV of the fuel;
 - (b) for cogeneration heaters: the ratio between the sum of the heat output and of the electric output multiplied by the electricity conversion factor of 2.65 in kW, and the heat input in kW in terms of the GCV of the fuel;
 - (c) for electric boilers: the ratio of the heat output in kW and the electric input in kW;

⁽⁴⁾ Directive 2024/1275/EU of the European Parliament and of the Council of 24 April 2024 on the energy performance of buildings, OJ L, 2024/1275, 8.5.2024, p. 1 ELI: <http://data.europa.eu/eli/dir/2024/1275/oj>).

⁽⁵⁾ Regulation (EU) 2024/573 of the European Parliament and of the Council of 7 February 2024 on fluorinated greenhouse gases, amending Directive (EU) 2019/1937 and repealing Regulation (EU) No 517/2014 (OJ L, 2024/573, 20.2.2024, ELI: <http://data.europa.eu/eli/reg/2024/573/oj>).

⁽⁶⁾ Regulation (EU) 2024/573 of the European Parliament and of the Council of 7 February 2024 on fluorinated greenhouse gases, amending Directive (EU) 2019/1937 and repealing Regulation (EU) No 517/2014 (OJ L, 2024/573, 20.2.2024, ELI: <http://data.europa.eu/eli/reg/2024/573/oj>).

- (32) 'standard rated heat input' (P_{hs}) of a fuel boiler heater or cogeneration heater means the heat input consumed when the heater is providing its maximum heat output in a 60/80 temperature regime, in kW, in terms of GCV;
- (33) 'standard rated electric power input' (EC) of an electric boiler heater is the electric power consumed at standard-rated heat output;
- (34) 'standard rated heat output' (P_4) of a fuel boiler heater, electric boiler heater, or cogeneration heater means the maximal heat output in a 60/80 temperature regime, expressed in kW;
- (35) 'part-load output' (P_1) of a fuel boiler heater means the heat output at 30 % of the standard-rated heat input P_{hs} in a 30/50 temperature regime, expressed in kW;
- (36) '30/50 temperature regime' means the 30 °C inlet and 50 °C outlet temperature for water;
- (37) 'minimum part-load output' (P_0) of a fuel boiler heater means the heat output with the lowest thermal input declared by the manufacturer that can be achieved without on/off cycling in a 30/50 temperature regime, expressed in kW;
- (38) 'turndown ratio' of a fuel boiler means the ratio between the lowest thermal input declared by the supplier that can be achieved without on/off cycling in a 30/50 temperature regime and P_{hs} , expressed in %;
- (39) 'nominal efficiency' (η_4) of a fuel boiler heater, electric boiler heater or cogeneration heater means the efficiency at standard-rated heat output;
- (40) 'efficiency at 30 % input' (η_1) means, for a fuel boiler heater, the space-heating efficiency at 30 % of the standard-rated heat input P_{hs} ;
- (41) 'efficiency at minimum heat input' (η_0) of a fuel boiler heater means the ratio between minimum part-load output (P_0) and standard-rated heat input (P_{hs});
- (42) 'full load auxiliary power' (e_{lmax}) means the electric power consumption, as part of the electric auxiliary energy, at standard-rated heat output P_4 of a fuel boiler heater or cogeneration heater, expressed in kW;
- (43) 'part load auxiliary power' (e_{lmin}) means the electric power consumption, as part of the electric auxiliary energy, at part load P_1 of a fuel boiler heater or cogeneration heater, expressed in kW;
- (44) 'standby heat loss' ($P_{h,l}$) means the heat loss of a boiler heater in operating modes without heat demand, expressed in kW;
- (45) 'standby heat loss correction factor' ($F(3)$) means a correction factor for the standby heat loss of boiler heaters and cogeneration heaters;
- (46) 'cogeneration electric power output' (P_{el}) is the electric power output of a cogeneration heater operating at standard-rated heat output, expressed in kW;
- (47) 'cogeneration part efficiency' (η_{CHP}) is the efficiency of the cogeneration heater when only the cogeneration heat generator is supplying heat, in a 30/50 temperature regime;
- (48) 'cogeneration part heat output' (P_{CHP}) is the heat output of the cogeneration, when only the cogeneration heat generator is supplying heat, in a 30/50 temperature regime, expressed in kW;

- (49) 'cogeneration part electric power output' (P_{el_CHP}) is the rated electric power output, when only the cogeneration heat generator is supplying heat, in a 30/50 temperature regime, expressed in kW;
- (50) 'cogeneration part heat input' (P_{input_CHP}) is the heat-input power in GCV of the liquid-fuel or gaseous-fuel input of the cogeneration, when only the cogeneration heat generator is supplying heat, in a 30/50 temperature regime, expressed in kW;

4. DEFINITIONS RELATED TO HEAT-PUMP HEATERS AND HYBRID HEAT-PUMP HEATERS

- (51) 'reference design conditions' means average climate conditions, for medium-temperature applications for MT and HT heat-pump heaters and for hybrid heat-pump heaters, and low-temperature applications for LT heat-pump heaters, in kW;
- (52) 'standard rating conditions' means the operating conditions of heaters under which they are tested to determine their standard-rated heat output, seasonal space-heating energy efficiency, water-heating energy efficiency, standard-rated cooling capacity, seasonal space-cooling energy efficiency, sound-power level and nitrogen oxide emissions;
- (53) 'operation limit temperature' (TOL) means the outdoor temperature below which the declared electric heat-pump heater capacity or the capacity of the electric heat-pump heat generator of the heat-pump or of the hybrid heat-pump heater is equal to zero, expressed in degrees Celsius, rounded up to the nearest higher integer value;
- (54) 'reference design temperature' means the outdoor temperature for either cooling ($T_{design,c}$) or heating ($T_{design,h}$) as described in Annex III, Table 11, at which the 'part-load ratio' is equal to 1 and which varies according to the cooling or heating season, expressed in degrees Celsius;
- (55) 'LT heat-pump heater' means a heat-pump heater declared to be capable of being used in a low-temperature application, but not in a medium-temperature nor in a high-temperature application;
- (56) 'MT heat-pump heater' means a heat-pump heater declared to be capable of being used in a medium-temperature application but not in a high-temperature application;
- (57) 'HT heat-pump heater' means a heat-pump heater declared to be capable of being used in a high-temperature application;
- (58) 'low temperature heating application' means an application where the heat-pump heater delivers heating at an indoor heat exchanger outlet temperature of 35 °C at design temperature, and at a specific water outlet temperature per part-load condition;
- (59) 'medium-temperature heating application' means an application where the heat-pump heater delivers heating at an indoor heat exchanger outlet temperature of 55 °C at design temperature, and at a specific water outlet temperature per part-load condition;
- (60) 'high temperature heating application' means an application where the heat-pump heater delivers heating at an indoor heat exchanger outlet temperature of 65 °C at design temperature, and at a specific water outlet temperature per part-load condition;

- (61) 'heat-pump heat source' designates the type of heat source or heat exchanger used at the evaporator side of a heat-pump heater or hybrid heat-pump heater: outdoor air, ventilation exhaust air (abbreviated as 'exhaust air'), ground heat exchanger (brine or water), or ground direct exchange (refrigerant);
- (62) 'design load' of a heat-pump heater or hybrid heat-pump heater ($P_{\text{design,h}}$) means the heat load at reference design conditions, expressed in kW;
- (63) 'reference design conditions' means the combination given in Annex III, Table 1, of:
 - (a) for heat-pump heaters in heating mode, the reference design temperature, the maximum bivalent temperature, maximum operation limit temperature, and if the heat-pump heater uses exhaust air, the maximum availability of exhaust air volume rates at $P_{\text{design,h}}$,
 - (b) for hybrid heat-pump heaters in heating mode, the reference design temperature, and if the heat-pump heater uses exhaust air, the maximum availability of exhaust air volume rates at $P_{\text{design,h}}$;
 - (c) for cooling, the reference design temperature;
- (64) 'reference design temperature' means the outdoor temperature for either cooling ($T_{\text{design,c}}$) or heating ($T_{\text{design,h}}$) as described in Annex III, Table 1, at which the 'part-load ratio' is equal to 1 and which varies according to the cooling or heating season, expressed in degrees Celsius;
- (65) 'bivalent temperature' (T_{biv}) means the lowest outdoor temperature point at which the heat-pump heater is declared to have a capacity able to meet 100% of the heating load, expressed in degrees Celsius, rounded up to the nearest integer value;
- (66) 'reference annual heating demand' (Q_{H}) means the reference heating demand for the heating season in a specific climate, to be used as the basis for calculating SCOP or SPER and calculated as the product of the design load for heating and the annual equivalent active-mode hours, expressed in kWh/a;
- (67) 'annual equivalent active mode hours' (H_{HE}) means the assumed annual number of hours in a specific climate a heat-pump heater or hybrid heat-pump heater has to provide the design load for heating to satisfy the reference annual heating demand, expressed in hours, as set out in Annex III, Table 2;
- (68) 'annual energy consumption' (Q_{HE}) means the energy consumption required to meet the reference annual heating demand for a designated heating season, expressed in kWh in terms of GCV and/or in kWh in terms of the final electricity consumption multiplied by CC;
- (69) 'heating season' means a set of operating conditions describing per bin the combination of outdoor temperatures and the number of hours these temperatures occur per season;
- (70) 'bin' (bin j) means a combination of an outdoor temperature and a number of hours;
- (71) 'outdoor temperature' (T_j) means the dry-bulb outdoor air temperature for bin j , expressed in degrees Celsius; the relative humidity may be indicated by a corresponding wet bulb temperature;
- (72) 'part-load ratio' ($pl(T_j)$) means the outdoor temperature T_j minus 16 °C divided by the reference design temperature $T_{\text{design,h}}$ minus 16 °C;

- (73) 'bin hours' (H_j) means the hours per heating or cooling season, expressed in hours per year, at which an outdoor temperature occurs for each bin;
- (74) 'part-load for heating' ($P_h(T_j)$) means the heating load at a specific outdoor temperature, calculated as the design load multiplied by the part-load ratio, expressed in kW;
- (75) 'part-load conditions' is the set of temperature conditions for testing at part-loads A, B, C, D, E and F;
- (76) 'Single speed heat-pump' means a heat-pump for which the heat output (resp. cooling capacity) can only adapt to the heating (resp. cooling) needs by cycling the compressor on and off.
- (77) 'minimum capacity for heating in continuous operation' ($P_{dh}(T_j)$) means the declared heating capacity a heat-pump heater is able to deliver, for an outdoor temperature T_j , expressed in kW;
- (78) 'backup capacity' ($P_{add}(T_j)$) is the difference between the part-load for heating and the maximum heat output of the main generator, for an outdoor temperature T_j , expressed in kW;
- (79) 'backup energy input' ($INPUT_{add}(T_j)$) is the energy input of the backup heater, for an outdoor temperature T_j , expressed in kW;
- (80) 'declared coefficient of performance' ($COP_d(T_j)$) means the declared coefficient of performance at the designated bins at T_j of the part-load conditions;
- (81) 'fuel utilisation efficiency' ($FUE_d(T_j)$) is the declared ratio between the part-load $P_h(T_j)$ and the measured thermal input in terms of GCV at a specific outdoor temperature T_j , expressed in kW/kW;
- (82) 'auxiliary electricity factor' ($AEF(T_j)$) is the ratio between the part-load $P_h(T_j)$ and the electric power input at a specific outdoor temperature T_j , expressed in kW/kW;
- (83) 'capacity ratio' (CR) is the part-load for heating $P_h(T_j)$ divided by the declared heating capacity $P_{dh}(T_j)$ of the heater at the same temperature T_j condition;
- (84) 'cycling' is the condition where the capacity ratio (CR) is smaller than 0.9 and the heat-pump heater will cycle on/off to reach the required part-load $P_h(T_j)$;
- (85) 'degradation coefficient' (C_{dh}) means the measure of efficiency loss due to cycling of heat-pump heaters; if C_{dh} is not determined by measurement then the default degradation coefficient is $C_{dh} = 0.9$;
- (86) 'adjusted outlet temperature for cycling' ($T_{cyc}(T_j)$) means the average outlet temperature during cycling of a heat-pump heater;
- (87) 'bin-specific coefficient of performance' ($COP_{bin}(T_j)$) means the coefficient of performance of the electric heat-pump heater, derived from the part-load for heating, declared capacity for heating and declared coefficient of performance for specified bins and calculated for other bins by interpolation or extrapolation, corrected where necessary by the degradation coefficient;
- (88) 'bin-specific primary energy ratio' ($FUE(T_j)$) means the fuel-utilisation efficiency of the fuel heat-pump heater, derived from the part-load for heating, declared capacity for heating and declared fuel utilisation efficiency for specified bins and calculated for other bins by interpolation or extrapolation, corrected where necessary by the degradation coefficient;

- (89) ‘active mode coefficient of performance’ (η) means the weighted average coefficient of performance of an electric heat-pump heater;
- (90) ‘active mode seasonal fuel utilisation efficiency’ (SFUE) means the seasonal FUE, calculated as the hour (h_j) weighted average of $FUE(T_j)$ over the designated heating season, expressed in kW/kW;
- (91) ‘active mode seasonal auxiliary electricity factor’ ($SAEF_{on}$) means the seasonal AEF in active mode, calculated as the hour (h_j) weighted average of $AEF(T_j)$ over the designated heating season, expressed in kW/kW;
- (92) ‘seasonal auxiliary electricity factor’ (SAEF) means the seasonal AEF, including electricity use in non-active modes Q_{aux} , calculated as the reference annual heating demand divided by the annual energy consumption, expressed in kW/kW;
- (93) ‘seasonal coefficient of performance’ (SCOP) means the annual average coefficient of performance of an electric heat-pump heater in the designated heating season, calculated as the reference annual heating demand divided by the annual energy consumption;
- (94) ‘seasonal coefficient of performance in active mode’ ($SCOP_{on}$) means the seasonal COP, calculated as the hour (h_j) weighted average of $COP(T_j)$ over the designated heating season, expressed in kW/kW;
- (95) ‘seasonal primary energy ratio’ (SPER) means the annual average primary energy ratio of a fuel heat-pump space-heater in the designated heating season, calculated from the SFUE and SAEF whereby the latter is converted to primary energy using CC;
- (96) ‘hybrid heat-pump heater electric resistance heat generator heat output’ ($elbu(T_j)$) means the heat output of an electric resistance heat generator supplementing the declared heat-pump capacity for heating to reach the part-load for heating $Ph(T_j)$ in the bin with temperature T_j , expressed in kW;
- (97) ‘hybrid heat-pump heater fuel heat generator capacity’ ($fuelbu(T_j)$) means the heat output of a fuel heat generator supplementing the declared heat-pump capacity for heating, as appropriate, to reach the part-load for heating $Ph(T_j)$ in the bin with temperature T_j , expressed in kW;
- (98) ‘off mode’ means a condition in which the heat-pump heater is connected to the mains power source and is not providing any function, or it is in a condition providing only:
- (a) an indication of its off-mode condition;
 - (b) functionalities intended to ensure electromagnetic compatibility pursuant to Directive 2014/30/EU of the European Parliament and of the Council⁽⁷⁾;
- (99) ‘thermostat-off mode’ of a heat-pump heater or hybrid heat-pump heater means the condition corresponding to the hours with no heating load and activated heating function, whereby the heating function is switched on, but the heat-pump-heater is not operational; cycling in active mode is not considered as thermostat-off mode;

(7) Directive 2014/30/EU of the European Parliament and of the Council of 26 February 2014 on the harmonisation of the laws of the Member States relating to electromagnetic compatibility OJ L 96, 29/03/2014, p. 79; ELI: <http://data.europa.eu/eli/dir/2014/30/oj>).

- (100) 'crankcase mode' means the condition in which a crankcase heating device is activated to avoid the refrigerant migrating to the compressor so as to limit the refrigerant concentration in oil when the compressor is started;
- (101) 'off mode power consumption' (P_{OFF}) means the power consumption of a heat-pump heater or hybrid heat-pump heater in off mode, expressed in kW;
- (102) 'thermostat-off mode power consumption' (P_{TO}) means the power consumption of the heat-pump heater or hybrid heat-pump heater while in thermostat-off mode, expressed in kW;
- (103) 'crankcase mode power consumption' (P_{CK}) means the power consumption of the heat-pump heater or hybrid heat-pump heater while in crankcase mode, expressed in kW;
- (104) 'hours in various operating modes' are the number of annual hours in active mode (H_{HE}), thermostat-off mode (H_{TO}), standby mode (H_{SB}), off mode (H_{OFF}) and crankcase mode (H_{CK}) for reversible and heating-only heat-pump heaters;
- (105) 'off mode operating hours' (H_{OFF}) means the annual number of hours [hrs/a] the unit is considered to be in off-mode, the value of which depends on the designated season and function;
- (106) 'thermostat-off mode operating hours' (H_{TO}) means the annual number of hours (hrs/a) the unit is considered to be in thermostat-off mode, the value of which depends on the designated season and function;
- (107) 'standby mode operating hours' (H_{SB}) means the annual number of hours [hrs/a] the unit is considered to be in standby mode, the value of which depends on the designated season and function;
- (108) 'crankcase mode operating hours' (H_{CK}) means the annual number of hours (hrs/a) the unit is considered to be in crankcase-heater-operation mode, the value of which depends on the designated season and function;
- (109) 'additional auxiliary electricity consumption' (Q_{aux}) of a heat-pump heater or the heat-pump heat generator comprising a hybrid heat-pump heater, means the annual auxiliary electricity consumption, in kWh/a, in thermostat-off mode, standby mode, off mode and crankcase heater mode from measured power and default hours in each mode;
- (110) 'maximum ventilation exhaust air flow rate for space-heating' ($q_{\text{v,maxh}}$) is the maximum flow rate of exhaust air at temperature conditions that can be used when assessing the space-heating efficiency;
- (111) 'switch temperature fuel boiler off' ($T_{\text{fb,off}}$) for a hybrid heat-pump heater means the outdoor air temperature above which the fuel backup heater is not providing any heating capacity as it is switched off by the controls and heat is only provided by the heat-pump heat generator;
- (112) 'switch temperature heat-pump on' ($T_{\text{hp,on}}$) for a hybrid heat-pump heater means the outdoor air temperature above which the heat-pump heat generator is switched on;
- (113) 'test conditions' means the test conditions defined in Annex III, Table 3;
- (114) 'frequency' in Hz is the number of rotations per second of the compressor or of the circulator or of the fan or of the engine of the heater;

5. DEFINITIONS RELATED TO THE COOLING FUNCTION IN REVERSIBLE HEAT-PUMP HEATERS AND HYBRID HEAT-PUMP HEATERS COMPRISING REVERSIBLE HEAT-PUMP

- (115) 'reversible heat pump heater' means a heat-pump heater capable of both cooling and heating;
- (116) 'cooling function' means providing chilled water to a water-based cooling system;
- (117) 'low cooling temperature application' means an application where the reversible heat-pump heater delivers cooling at an indoor heat exchanger outlet temperature of 7 °C at design temperature, and at a specific water outlet temperature per part-load condition;
- (118) 'medium cooling temperature application' means an application where the reversible heat-pump heater delivers cooling at an indoor heat exchanger outlet temperature of 18 °C at design temperature, and at a specific water outlet temperature per part-load condition;
- (119) 'free cooling' means free cooling as defined in Annex VII, Part B, Section 1 of the Directive 2018/2001 ⁽⁸⁾;
- (120) 'water-based cooling system' means the components or equipment necessary for the distribution of chilled water and the transfer of heat from indoor spaces to chilled water, where the purpose of the system is to attain and maintain the desired indoor temperature of an enclosed space, such as a building or parts thereof, for the thermal comfort of human beings;
- (121) 'standard rated cooling capacity' ($P_{SR,c}$) means the cooling capacity of a reversible heat-pump when providing space cooling at 'standard rating conditions', expressed in kW;
- (122) 'seasonal space cooling energy efficiency' ($\eta_{s,c}$) means the ratio between the reference annual cooling demand pertaining to the cooling season covered by a heater, and the annual energy consumption for cooling, corrected by contributions accounting for temperature control and the electricity consumption of ground water pump(s), where applicable, expressed in %;
- (123) 'seasonal energy-efficiency ratio' ($SEER$) is the overall energy-efficiency ratio of the heater, representative for the cooling season, calculated as the 'reference annual cooling demand' divided by the 'annual energy consumption for cooling';
- (124) 'reference annual cooling demand' (Q_C) means the reference cooling demand to be used as the basis for the calculation of $SEER$ and calculated as the product of the design cooling load ($P_{design,c}$) and the equivalent active-mode hours for cooling (H_{CE}), expressed in kWh;
- (125) 'annual energy consumption for cooling' (Q_{CE}) means the energy consumption required to meet the 'reference annual cooling demand' and is calculated as the 'reference annual cooling demand' divided by the 'active mode seasonal energy-efficiency ratio' ($SEER_{on}$) and the electricity consumption of the unit for thermostat-off, standby, off and crankcase mode during the cooling season, expressed in kWh;

⁽⁸⁾ Directive (EU) 2018/2001 of the European Parliament and of the Council of 11 December 2018 on the promotion of the use of energy from renewable sources (*OJ L 328, 21.12.2018, pp. 82–209, ELI: <http://data.europa.eu/eli/dir/2018/2001/oj>*).

- (126) ‘design cooling load’ ($P_{design,c}$) means the cooling load applied to a heater at the cooling reference design conditions defined in Annex III, Table 1, whereby the design cooling load ($P_{design,c}$) is equal to the declared cooling capacity at outdoor temperature (T_j) equal to the reference design temperature for cooling ($T_{design,c}$), expressed in kW;
- (127) ‘maximum ventilation exhaust air flow rate for space cooling’ ($q_{v,maxc}$) is the maximum flow rate of exhaust air at temperature conditions that can be used when assessing the seasonal space cooling energy-efficiency;
- (128) ‘equivalent active mode hours for cooling’ (H_{CE}) means the assumed annual number of hours the unit shall provide the ‘design cooling load’ ($P_{design,c}$) in order to satisfy the ‘reference annual cooling demand’, expressed in hours;
- (129) ‘active mode seasonal energy-efficiency ratio’ ($SEER_{on}$) means the average energy-efficiency ratio of the unit in active mode for the cooling function, constructed from part-load and bin-specific energy-efficiency ratios ($EER_{bin}(T_j)$) and weighted by the bin hours in which the bin condition occurs;
- (130) ‘cooling part-load ratio’ ($plc(T_j)$) means the outdoor temperature T_j minus 16 °C divided by the reference design temperature $T_{design,c}$ minus 16 °C;
- (131) ‘part-load for cooling’ ($Pc(T_j)$) means the cooling load at a specific outdoor temperature, calculated as the design cooling load multiplied by the part-load ratio and expressed in kW;
- (132) ‘bin-specific energy-efficiency ratio’ ($EER_{bin}(T_j)$) means the energy-efficiency ratio specific for every bin_j with outdoor temperature (T_j) in a season, derived from the part-load, declared capacity and declared energy-efficiency ratio ($EER_d(T_j)$) and calculated for other bins through interpolation/extrapolation, when necessary corrected by the applicable degradation coefficient;
- (133) ‘seasonal primary energy ratio in cooling mode’ ($SPER_c$) means the overall energy-efficiency ratio of the air conditioner or comfort chiller using fuels, representative for the cooling season;
- (134) ‘seasonal fuel utilisation efficiency in cooling mode’ ($SFUE_c$) means the fuel utilisation efficiency for the whole cooling season;
- (135) ‘seasonal auxiliary energy factor in cooling mode’ ($SAEF_c$) means the auxiliary energy-efficiency for the cooling season, including the contribution of thermostat-off mode, standby mode, off mode and crankcase-heater mode power modes;
- (136) ‘fuel utilisation efficiency at partial load’ means the fuel-utilisation efficiency when cooling ($FUE_{c,bin}$) at outdoor temperature T_j ;
- (137) ‘auxiliary energy factor in cooling mode at partial load’ ($AEF_{c,bin}$) means the auxiliary energy-efficiency when cooling at outdoor temperature (T_j);

6. DEFINITIONS RELATED TO WATER HEATING IN COMBINATION HEATERS

- (138) ‘water heating energy-efficiency’ (η_{wh}) means the ratio between the useful energy in the drinking or sanitary water provided by a combination heater and the energy required for its generation, expressed in %;
- (139) ‘out of the box mode’ means the standard operating condition, setting or mode set by the manufacturer at factory level, to be active immediately after the heater

installation, suitable for normal use by the end user according to the declared load profile;

- (140) 'load profile' means a sequence of water draw-offs, as specified in Annex III, Table 7; each combination heater meets at least one load profile;
- (141) 'mixed water at 40 °C' (V40), expressed in litres, is the equivalent of 40 °C water that the heater can deliver in standard conditions;
- (142) 'water draw-off' means a given combination of useful water flow rate, useful water temperature, useful energy content and draw-off temperature, as specified in Annex III, Table 7;
- (143) 'useful water flow rate' (f) means the minimum flow rate, expressed in litres per minute, for which hot water is contributing to the reference energy, as specified in Annex III, Table 7;
- (144) 'useful water temperature' (T_m) means the water temperature, expressed in degrees Celsius, at which hot water starts contributing to the reference energy, as specified in Annex III, Table 7;
- (145) 'useful energy content' (Q_{tap}) means the energy content of hot water, expressed in kWh, provided at a temperature equal to, or above, the useful water temperature, and at water flow rates equal to, or above, the useful water flow rate, as specified in Annex III, Table 7;
- (146) 'energy content of hot water' means the product of the specific heat capacity of water, the average temperature difference between the hot-water output and cold-water input, and the total mass of the hot water delivered;
- (147) 'draw-off temperature' (T_p) means the average water temperature, expressed in degrees Celsius, to be achieved during water draw-off, as specified in Annex III, Table 7;
- (148) 'reference energy' (Q_{ref}) means the sum of the useful energy content of water draw-offs, expressed in kWh, in a particular load profile, as specified in Annex III, Table 7;
- (149) 'maximum load profile' means the tapping load profile with the greatest reference energy that a combination heater is able to provide while fulfilling the temperature and flow rate conditions of that load profile;
- (150) 'daily electricity consumption' (Q_{elec}) means the consumption of electricity for water heating over 24 consecutive hours under the declared load profile, expressed in kWh in terms of final energy;
- (151) 'daily electricity generation' (Q_{elec_gen}) means the generation of electricity by cogeneration combination heaters for water heating over 24 consecutive hours under the maximum load profile, expressed in kWh in terms of final energy;
- (152) 'daily fuel consumption' (Q_{fuel}) means the consumption of fuels for water heating over 24 consecutive hours under the declared load profile, expressed in kWh in terms of GCV;
- (153) 'annual electricity consumption' (AEC) means the annual electricity consumption of a combination heater for water heating under the declared load profile and under given climate conditions, expressed in kWh in terms of final energy;

- (154) 'annual fuel consumption' (AFC) means the annual fuel consumption of a combination heater for water heating under the declared load profile and under given climate conditions, expressed in GJ in terms of GCV;
- (155) 'ambient correction term' (Q_{cor}) means a term which considers the fact that the place where the combination heater is installed is not an isothermal place, expressed in kWh;
- (156) 'self-learning' means a function of the combination heater that automatically captures the end-user's use patterns of the water-heating functionality of the combination heater;
- (157) 'adaptive control' means a control which adapts the temperature of the water stored in the combination heater depending on the use patterns captured with the self-learning function of the combination heater;
- (158) 'adaptive control factor' (F_{AC}) means the water heating energy-efficiency gain due to adaptive control under the conditions set out in Annex III, Section 5.2, sub (b);
- (159) 'adapt' is a Boolean either equal to 0 or to 1;
- (160) 'weekly electricity consumption with adaptive controls' ($Q_{elec,week,adaptive}$) means the weekly water heating electricity consumption of a combination heater with the adaptive control function enabled, expressed in kWh electricity;
- (161) 'weekly fuel consumption with adaptive controls' ($Q_{fuel,week,adaptive}$) means the weekly water heating fuel consumption of a combination heater with the adaptive control function enabled, expressed in kWh in terms of GCV;
- (162) 'weekly electricity consumption without adaptive controls' ($Q_{elec,week}$) means the weekly water heating electricity consumption of a combination heater with the adaptive control function disabled, expressed in kWh;
- (163) 'weekly fuel consumption without adaptive controls' ($Q_{fuel,week}$) means the weekly water heating fuel consumption of a combination heater with the adaptive control function disabled, expressed in kWh in terms of GCV;
- (164) 'control factor' (F_{ctrl}) means a factor accounting for the capability of instantaneous water heaters to set the water temperature independently of the water flow;
- (165) 'Passive Flue Heat Recovery Device' (PFHRD) means a device integrated in the appliance or supplied with the appliance to transmit waste heat from the combustion products to the domestic hot water, as set out in Annex III, Section 5;
- (166) 'maximum ventilation exhaust air flow rate for water heating' ($q_{v,maxw}$) is the maximum flow rate of exhaust air at temperature conditions, as set out in Annex III, Table 6, that can be used when assessing the water-heating efficiency;
- (167) 'off-peak combination heater' means a combination heater that is able to work in an off-peak application;
- (168) 'off-peak application' means the ability of the water heater to be automatically (without the intervention of the end-user each time) energised for a maximum period of 8 consecutive hours between 22:00 and 07:00 of the 24-hour tapping pattern in the load profiles, as set out in Annex III, Section 5;

7. DEFINITIONS RELATED TO SOLAR DEVICES

- (169) ‘solar collector’ means a device designed to absorb solar irradiance and to transfer the thermal energy so produced to a fluid passing through it;
- (170) ‘Gross thermal yield’ (GTY) means the reference annual thermal yield of the collector array of the solar device for a specific climate, in kWh/a, as set out in Annex VII, Section 7, calculated as the simple average of the thermal yield for the 25°C and 50°C collector operating temperature, in kWh/a;
- (171) ‘Gross area’ (A_g) means the maximum projected area covered by the outer dimensions of the collector array, expressed in m²;
- (172) ‘solar device efficiency for space-heating’ ($\eta_{sol,sh}$) means the efficiency of a solar device for space-heating, considering the energy-efficiency class of the tank if applicable, calculated by multiplying the solar device factor by the tank-correction factor and expressed in %;
- (173) ‘solar device factor for space-heating’ ($f_{sol,sh}$) means a factor (>1) for the contribution of a solar device to the seasonal space-heating efficiency of a space-heater comprising a package, as set out in Annex III, Section 8 and Section 10;
- (174) ‘solar device efficiency for water heating’ ($\eta_{sol,wh}$) means the efficiency of a solar device for water heating, considering the energy-efficiency class of the tank if applicable, calculated by multiplying the solar-device factor with the tank-correction factor, and expressed in %;
- (175) ‘solar device factor for water heating’ ($f_{sol,wh}$), means a factor (>1) representing the contribution of a solar device to the water heating efficiency of a package of combination heater and solar device, as set out in Annex III, Section 8 and Section 11;
- (176) ‘tank factor’ (f_{tank}) means a factor in the calculation of the solar device efficiency that depends on the energy-efficiency class of the solar hot-water storage tank, as set out in Annex III, Section 8;
- (177) ‘non solar heat required’ Q_{nonsol} is the part of the annual water heating demand which is not covered by the solar-device yield and therefore shall be provided by the water heater, in kWh/a;
- (178) ‘annual solar water heating demand’ $Q_{wh,sol}$ is the water-heating demand per year to be met by the combination of solar device and water heater, in kWh/a;
- (179) ‘solar heat delivered’ Q_{sol} is the part of the annual water-heating demand that is covered by the solar-device yield, in kWh/a;

8. DEFINITIONS RELATED TO HOT WATER STORAGE TANKS

- (180) ‘standing loss’ (S) means the heating power dissipated from a hot-water storage tank at standard-rating conditions, expressed in W;

9. DEFINITIONS RELATED TO SHOWER WATER HEAT RECOVERY DEVICES

- (181) ‘shower water heat recovery device factor’ ($f_{SWHRD,lp}$) means a factor representing the water-heating energy-efficiency gains of a combination-heater package comprising a shower-water heat-recovery device for a specific load profile;

- (182) ‘shower water heat recovery efficiency’ ($\eta_{\text{SWHRD,lp}}$) means the thermal efficiency of the shower-water heat-recovery device calculated as the ratio of the heat recovered by the device divided by the heat supplied to the device for a specific load profile;

10. DEFINITIONS RELATED TO PACKAGES

- (183) ‘package seasonal space-heating efficiency’ ($\eta_{s,pack}$) means the ratio between the space-heating demand supplied by the package and the annual energy consumption required to meet this demand, expressed in %
- (184) ‘package water heating energy efficiency’ ($\eta_{wh,pack}$) means the ratio between the useful energy provided by a water heating package and the energy required for its generation, expressed in %;

11. DEFINITIONS RELATED TO TEST METHOD

- (185) ‘compensation method’ means a dynamic test method in which the space-heater is delivering heating (or cooling) to a water loop of representative physical or simulated inertia to maintain an indoor air or water temperature set-point by compensating for a given physical or simulated heating (or cooling) load;

ANNEX II

Ecodesign requirements

1. REQUIREMENTS FOR SPACE-HEATING ENERGY EFFICIENCY

1.1. Minimum space-heating energy-efficiency requirements

The seasonal space-heating energy efficiency $\eta_{s,h}$ (in %) of the specified heaters in average climate conditions shall not be lower than the values given in Table 1.

1.2. Modulation requirements for boilers

1. The turndown ratio of fuel boiler heaters using gaseous fuels with a standard-rated heat output lower than or equal to 70 kW, with the exemption of B1 boiler heaters, shall be lower than or equal to 20 %.
2. The turndown ratio of fuel boiler heaters with a standard-rated heat output lower than or equal to 70 kW using liquid fuels, with the exemption of B1 boiler heaters, shall be lower than or equal to 40 %.

Table 1

Minimal seasonal space-heating efficiency

No.	Heater type	$\eta_{s,h}$ (%)
1.	B1 fuel boiler space-heater with a standard-rated heat output of 10 kW or less	76
2.	B1 fuel boiler combination heater with a standard-rated heat output of 30 kW or less	76
3.	Fuel boiler heater with a standard-rated heat output of more than 70 kW (η_{l1} and η_{l4})	92 (η_{l1}) 95 (η_{l4})
4.	Fuel boiler heater other than indicated in rows 1-3, for which fuel is declared as the main space-heating energy source	92
5.	Electric boiler heater	48
6.	Others*	100

**packages are not included; there are no minimum seasonal space-heating efficiency requirements for packages, only for heaters included in packages*

1.3. Requirements for heat-pumps

1. Heat pumps are at least able to work at low temperature heating application and/or at medium temperature application in average climate conditions.
2. Reversible heat pumps are at least able to work at low temperature cooling application and/or at medium temperature cooling application in cooling conditions.
3. Regarding heat-pump heaters and hybrid heat-pump heaters that (i) are not single speed heat-pumps and (ii) that have a standard-rated heat output of 70 kW or less, the

use of the compensation method for the assessment of the seasonal space heating energy efficiency and of the seasonal space cooling energy efficiency should be introduced as set in Article 11 of the present Regulation;

4. Heat-pump heaters and hybrid heat-pump heaters tested according to the compensation method shall not cycle on/off when tested for compensation loads equal to or higher than the declared heating (respectively cooling) output of the unit in continuous operation A, B, C, D, E, F and G defined in Annex III Table 3 (respectively A, B, C and D defined in Annex III Table 9 in cooling mode).

2. REQUIREMENTS FOR WATER HEATING

2.1. Declared load profile

The load profile for the calculation of the water heating energy efficiency shall be the maximum load profile.

For heat pumps using outdoor air, the load profiles may be different for the three (average, colder and warmer) climate conditions.

2.2. Water heating energy-efficiency requirements

The water heating energy-efficiency (η_{wh}) of specified combination heaters, in % for specified load profiles defined in Annex III, shall not be lower than the values indicated in Table 2.

Table 2
Minimal water heating energy-efficiency requirements

		Declared load profile						
		S	M	L	XL	XXL	3XL	4XL
No.	Combination heater type	η_{wh} (%)						
1.	Electric boiler heater	42	48	48.6	48.6	83	88	88
2.	B1 boiler heater with a standard-rated heat output of 30 kW or less	45	70	70	75	76	76	76
3.	Heater other* than indicated in rows 1-2	45	70	75	80	83	88	88

*packages are not included

2.3. Mixed water at 40 °C amount requirements

The minimum amount of mixed water at 40 °C that can be provided by a combination heater shall not fall below the values indicated in Table 3.

Table 3
Minimum amount of mixed water at 40 °C

Declared load profile

	M	L	XL	XXL	3XL	4XL
Mixed water at 40 °C (litres)	65	130	210	300	520	1040

2.4. Water supply at 50 °C requirement

Combination heaters shall be able to supply water at 50 °C in ‘out of the box mode’ when required in the load profile. For outdoor air heat pump combination heaters, this requirement shall also apply for warmer and colder climate conditions.

3. REQUIREMENTS FOR SOUND-POWER LEVEL

The sound-power level of heaters in heating mode shall not exceed the values indicated in Table 4 when providing space-heating.

Heat-pumps and hybrid heat-pumps shall use the test settings indicated in article 11 of this regulation to measure sound-power levels.

Table 4
Maximum sound-power level

P ₄ of the boiler or cogeneration, P _{designh} of the heat-pump heater or hybrid heat-pump heater	Sound-power level (L _{WA}) in dB(A)	
	Outdoor	Indoor
≤ 6 kW	65	60
> 6 kW and ≤ 12 kW	70	65
> 12 kW and ≤ 30 kW	78	70
> 30 kW and ≤ 70 kW	88	80

4. REQUIREMENTS RELATED TO EMISSIONS OF NITROGEN OXIDES

1. Emissions of nitrogen oxides, expressed in nitrogen dioxide, of heaters using liquid or gaseous fuels shall not exceed the values indicated in Table 5.
2. In case the heat-pump heater is declared for use in medium-temperature heating applications and/or low-temperature application it shall meet the requirement regarding nitrogen oxides emissions in medium-temperature heating applications.
3. In case the heat-pump heater is declared for use in low-temperature heating applications only, it shall meet the requirement regarding nitrogen oxides emissions in low-temperature heating applications.

4. The values given in the Table 5 referring to heaters using gaseous fuels apply to heaters using second-family gases, to be tested with G20 reference gas, and gas heaters only used with G25 reference gas.
5. For boiler heaters (including boiler heaters in hybrid heaters) using only third family gases, to be tested with G30 reference gas, the emissions of nitrogen oxides, expressed in nitrogen dioxide, of heaters shall not exceed the limit values for second family gases indicated in Table 5, multiplied by a factor 1.30.
6. For boiler heaters (including boilers in hybrid heaters) using only propane, to be tested with G31 reference gas, the emissions of nitrogen oxides, expressed in nitrogen dioxide, of heaters shall not exceed the limit values for second-family gases indicated in Table 5, multiplied by a factor 1.20.

Table 5
Maximum emissions of nitrogen oxides

Heater type	Maximum NO_x emissions in mg/kWh fuel input
Fuel boiler heaters using gaseous fuels	56
Fuel boiler heaters using liquid fuels	92
Cogeneration space-heaters with external combustion using gaseous fuels	70
Cogeneration space-heaters with external combustion using liquid fuels	92
Cogeneration space-heaters with internal combustion engine using gaseous fuels	240
Cogeneration space-heaters with internal combustion engine using liquid fuels	392
Fuel heat-pump heaters equipped with external combustion engine using gaseous fuels	70
Fuel heat-pump heaters equipped with external combustion engine using liquid fuels	92
Fuel heat-pump heaters equipped with an internal combustion engine using gaseous fuels	240
Fuel heat-pump heaters equipped with an internal combustion engine using liquid fuels	392

5. REQUIREMENTS FOR MATERIAL RESOURCE EFFICIENCY

5.1. Applicability

Requirements set out in this section shall apply to heaters with a standard-rated heat output of 70 kW or less.

5.2. Availability of spare parts

7. For all heaters placed on the market as from dd.mm.yyyy *[the date = 24 months after the date of entry into force of this Regulation – OP – Please insert reference]*

manufacturers, importers or authorised representatives shall make available to professional repairers at least the following spare parts:

- (a) the circulator and its parts (including flow rate control),
- (b) ignition spark plugs,
- (c) sensors (including thermostats, pressure gauge, control sensors, other sensors for temperature or pressure),
- (d) electric fuses (separately or bundled together),
- (e) proprietary seals and connection means (including special bolts, nuts, washers, and clamps),
- (f) fans or fan assemblies (including fan motors and fan wheels),
- (g) compressors and their parts,
- (h) burners,
- (i) flow meters,
- (j) printed circuit boards,
- (k) valves and actuators, (including electrically operated valves, 3-way valve, and gas valves),
- (l) the heater housing and its parts,
- (m) heat generators and their parts,
- (n) heat exchangers,
- (o) piping,
- (p) gaskets and seals,
- (q) buttons, switches, and knobs,
- (r) impellers,
- (s) cables and plugs,
- (t) displays and status indicators,
- (u) software and firmware, including reset software;

8. Manufacturers, importers or authorised representatives shall make available to end-users at least the following spare parts:

- (a) Remote control

9. Availability of spare parts referred to in points 1 and 2 of the present section shall be ensured for a minimum period that starts either on dd.mm.yyyy *[the date = 24 months after the date of entry into force of this Regulation – OP – Please insert reference]* or when the first unit of the concerned model is placed on the market or put into service, whichever is the latest, and ends at least, ten years after the last unit of that model is placed on the market or put into service (the ‘minimum period’).

10. To ensure such availability for the entire minimum period, manufacturers, their authorised representatives or importers shall provide a list of spare parts indicative pre-tax prices, at least in euro, for all spare parts listed in points 1 and 2 of the present section, including the indicative pre-tax price of fasteners and tools, if

supplied with the spare part, and the instructions for ordering them and on the free access website of the manufacturer, authorised representative or importer.

11. Manufacturers, authorised representatives or importers of heaters shall ensure that the spare parts mentioned in points 1 and 2 can be replaced without tools or with tools that are not proprietary tools and without permanent damage to the heater.
12. When manufacturers, authorised representatives or importers make available software and firmware updates for heaters using software, these shall remain available for a minimum of ten years after the placing of the last unit of that heater on the market, and those updates shall be provided free of charge.

5.3. Maximum delivery time for spare parts

During the minimum period, manufacturers, importers or authorised representatives shall ensure the delivery of the spare parts within 15 working days after having received the order.

5.4. Access to repair and maintenance information

1. Manufacturers, importers or authorised representatives shall, during the minimum period referred to in point 5.2.3, provide access to the repair and maintenance information to professional repairers considering the following:
 - (a) the manufacturer's, importers or authorised representative's website shall indicate the process for professional repairers to request access to the repair and maintenance information; to accept such a request, the manufacturers, importers or authorised representatives may only require the professional repairer to demonstrate that:
 - (i) the professional repairer has the technical skill to repair heaters and complies with the applicable regulations for repairers of the heaters in the Member States where it operates; reference to an official registration system as professional repairer, where such a system exists in the Member States concerned, shall be accepted as proof of compliance with this point;
 - (ii) the professional repairer is covered by insurance covering liabilities resulting from its activity regardless of whether this is required by the Member State.
 - (b) the manufacturers, importers or authorised representatives shall accept or refuse the request within five working days;
 - (c) manufacturers, importers or authorised representatives may charge reasonable and proportionate fees for access to the repair and maintenance information or for providing regular updates; a fee is reasonable only if it does not discourage access by failing to consider the extent to which the professional repairer uses the information;
 - (d) once the request is accepted, a professional repairer shall have access, within one working day, to the requested repair and maintenance information. The information may be provided for an equivalent model or one of the same product ranges, if relevant;
 - (e) the heater repair and maintenance information referred to in point (1) shall include:
 - (i) the unequivocal heater identification;

- (ii) a disassembly map or exploded view;
 - (iii) a technical manual of instructions for repair;
 - (iv) a list of necessary repair and test equipment;
 - (v) component and diagnosis information (such as minimum and maximum theoretical values for measurements);
 - (vi) wiring and connection diagrams;
 - (vii) diagnostic fault and error codes (including manufacturer-specific codes, where applicable);
 - (viii) instructions for installation of relevant software and firmware including reset software;
 - (ix) information on how to access data stored on the heater, including data stored in accordance with Section 7 point 7.4 and records of reported failure incidents stored on the heater (where applicable);
 - (x) electronic board diagrams.
2. Without prejudice to intellectual property rights, third parties shall be allowed to use and publish unaltered repair and maintenance information initially published by the manufacturer, importer or authorised representative and covered by point (e) once the manufacturer, importer or authorised representative terminates access to that information after the end of the period of access to repair and maintenance information.

5.5. Dismantling for material recovery and recycling while avoiding pollution

Manufacturers, importers or authorised representatives shall ensure that heaters are designed in such a way that the materials and components referred to in Annex VII to Directive 2012/19/EU of the European Parliament and of the Council ⁽⁹⁾ can be removed without tools or with tools that are not proprietary tools.

6. PRODUCT-INFORMATION REQUIREMENTS

1. With effect from dd.mm.yyyy *[the date = 24 months after the date of entry into force of this Regulation – OP – Please insert reference]*, the information on products set out in point 2 to 8 of this section:
- a. in the technical documentation for the purposes of conformity assessment;
 - b. in the user manual supplied with the product;
 - c. on the free access websites of the manufacturer, its authorised representative or the importer, for a period of at least 10 years after the placing on the market of the last unit of the model concerned.
2. The following product information shall be included or displayed as indicated in point 1 of this section:
- a. for fuel boiler heaters – Table 6;
 - b. for electric boiler heaters – Table 7;

⁽⁹⁾ Directive 2012/19/EU of the European Parliament and of the Council of 4 July 2012 on waste electrical and electronic equipment (WEEE). (OJ L 197, 24.7.2012, p. 38; ELI: <http://data.europa.eu/eli/dir/2012/19/oj>)

- c. for cogeneration heaters – Table 8;
- d. for cogeneration heaters with a backup boiler Table 9;
- e. for heat-pump heaters and hybrid heat-pump heaters – Table 10 (in this table, information for high-temperature applications is optional) and part A of Table 11 only for average climate and medium-temperature heating applications, or for average climate and low-temperature heating applications for heat pump heaters that cannot operate in average climate and medium-temperature heating applications;
- f. for reversible heat-pump heaters and hybrid heat-pump heaters, additionally the information set out in part A of Table 12;
- g. for combination heaters, information set out in Table 13 for the load profile declared in accordance with Section 2.1; for outdoor heat pump combination heater, the information set in Table 13 for average climate conditions, for colder climate and for warmer climate conditions;
- h. for temperature controls – Table 14;
- i. for solar devices – Table 15;
- j. for shower water heat recovery devices – Table 16;
- k. for packages – Table 17.

If a given parameter is not applicable to the product, the expression ‘N/A’ shall identify it as not applicable.

3. For products or packages in the scope of Regulation (EU) [2026/ xxx] *[the reference to the energy regulation to be published on the same date ⁽¹⁰⁾ – OP – Please insert reference]*, the link to the model of the product or to the model of the package in the European Product Registry for Energy Labelling (EPREL) as a human-readable Uniform Resource Locator (URL) or as QR code or by providing the product or package registration number.
4. As regards self-monitoring data, information on:
 - (a) how the end-user or third parties can access the data stored in accordance with Section 7.4 of this Annex;
 - (b) how the access to data by third parties can be granted and revoked by the end-user;
 - (c) the remote collection and reporting of data by the manufacturer (if applicable).
5. Any specific precautions that shall be taken when the heater is assembled, installed or maintained.
6. For B1 boiler heaters and electric boiler heaters, the following standard text:

This heater contains a natural draught boiler, which is intended to be connected only to a flue shared between multiple dwellings in existing buildings that evacuates the

⁽¹⁰⁾ COMMISSION DELEGATED REGULATION (EU) .../2026 of XXX supplementing Regulation (EU) 2017/1369 of the European Parliament and of the Council with regard to the energy labelling of space heaters, combination heaters, temperature controls, solar devices, shower water heat recovery devices and packages of those products, amending and repealing Commission Delegated Regulation (EU) No 812/2013 *[the publication reference of what we call the sister regulation on energy labelling which will be published on the same date – OP – Please insert reference]*.

residues of combustion to the outside of the room containing the boiler. It draws the combustion air directly from the room and incorporates a draught diverter. Due to lower efficiency, any other use of this boiler shall be avoided and would result in higher energy consumption and higher operating costs.

7. Along the availability of specific operating modes such as ‘eco mode’ or ‘low noise mode’ also the impact on heating output (or cooling output or electric output), energy consumption and seasonal space heating (and possibly water heating and/or cooling) energy efficiency, using one or several test conditions necessary to calculate the seasonal space heating (and possibly water heating and/or cooling) energy efficiency.
8. For energy-smart appliances in case the manufacturer includes a logo pursuant to the requirements of section 9 indicating that the product complies (interoperability of energy smart appliances), the information in part A of the Table 18 of this annex;

7. ADDITIONAL INFORMATION TO BE PART OF THE TECHNICAL DOCUMENTATION

The technical documentation for the purposes of both conformity assessment and verification procedures shall, in addition to the information listed in point 6.2, contain the following elements:

1. a general description of the model, allowing it to be unequivocally and easily identified, and of its intended use;
2. references to the harmonised standards applied or other measurement standards used;
3. detailed information for verification as follows:
 - (a) for heat-pump heaters and hybrid heat-pump heaters – one part B of Table 11 of this annex for each combination of climate and temperature application for which a seasonal space heating energy efficiency value has been declared in part A of Table 11;
 - (b) for reversible heat-pump heaters and hybrid heat-pump heaters – one part B of Table 12 of this annex for each temperature application for which a seasonal space cooling energy efficiency value has been declared in part A of Table 12;
 - (c) for energy-smart appliances in case the manufacturer includes a logo pursuant to the requirements of section 9 indicating that the product complies (interoperability of energy smart appliances), the part B of Table 18 of this annex;
4. the details and the results of calculations performed in accordance with Annex III;
5. testing conditions, where they are not described sufficiently in the references provided pursuant to point 2;
6. a list of all equivalent models, including the model identifier;
7. where the information included in the technical documentation for a particular model has been obtained either from a model that has the same technical characteristics relevant for the technical information to be provided but is produced by a different manufacturer, or by calculations based on design or extrapolation from another model of the same or a different manufacturer, or both, the following:
 - (a) the details of the calculations, including a detailed mathematical model;

- (b) the details of the assessment undertaken by the manufacturer to verify the accuracy of the calculation, including detailed description of any tests undertaken to verify the accuracy of the calculations;
 - (c) where appropriate, the declaration of identity between the models of different manufacturers.
8. For products that are subject to third party conformity assessment procedures pursuant to the present Regulation the technical documentation shall also contain:
- (a) the identification number of the relevant notified body;
 - (b) the initial date at which the product was first placed on the market.

The technical documentation shall include the information in the order and as set out in Annex V of the Regulation (EU) [2026/ xxx] *[the reference to the energy regulation to be published on the same date (see footnote 10) – OP – Please insert reference]*.

8. INFORMATION TO BE PROVIDED ON THE PRODUCT

- 1. For B1 boiler heaters, the following information shall be durably marked on the product: ‘type B1 boiler’ or ‘type B1 combination boiler’, as applicable.
- 2. For cogeneration space-heaters, the standard-rated electric output in kW shall be durably marked on the product.

9. USE OF SMART APPLIANCE LOGO AND INFORMATION TO BE PROVIDED ON THE INTEROPERABILITY OF THE ENERGY SMART APPLIANCES

- 1. The smart appliance logo can be affixed on the product, on the packaging and/or in the instructions manual provided the conditions of points 2 to 4 below are satisfied.
- 2. In case the interoperability logo set out in Annex III, point 1.(a).X of the [Commission delegated regulation EU EU) .../2026 of XXX on energy label for space heaters] is affixed on the product, on the packaging and/or in the instructions manual, it shall be:
 - (a) clearly visible, indelible and shall have a height of at least 5 mm when affixed to the nameplate, or 7 mm when affixed to the enclosure, packaging or the instruction manual. If the logo is enlarged, the proportions set out in the drawings shall be maintained.
 - (b) The reference colours for the logo shall be black and white.
 - (c) However if the logo is used on a dark background, the interoperability logo may be used in a negative format using the same background colour.
 - (d) If the product nameplate enclosure packaging or instructions only use a black and white format or other analogous monochrome formats, the interoperability logo may use only those colours.
- 3. The information on interoperability of products set out in Table 18, parts A and B, shall be part of the technical documentation for the purposes of conformity assessment.

4. The information on interoperability of products set out in Table 18, part A shall be included in the user or instruction manuals and displayed visible in free access website of manufacturers, authorised representatives and importers.

Table 6
Fuel boiler heaters

Fuel boiler heater					
Brand or trademark:		Model identifier:			
Space-heating energy-efficiency class ⁽¹⁾ :					
Fuel type:		Gaseous fuel <input type="checkbox"/> Liquid fuel <input type="checkbox"/>			
If gaseous fuel: <input type="checkbox"/>		Reference gas: G20 <input type="checkbox"/> G25 <input type="checkbox"/> G30 <input type="checkbox"/> G31 <input type="checkbox"/>		B1 boiler heater: <input type="checkbox"/>	
				Combination heater: <input type="checkbox"/>	
				PFHRD: <input type="checkbox"/>	
Heat output and input			Space-heating efficiency		
Parameter	Value	Unit	Parameter	Value	Unit
Standard-rated heat output (P ₄)	x,x	kW	Seasonal space-heating efficiency ($\eta_{s,h}$)	x,x	%
Standard-rated heat input (P _{hs})	x,x	kW	Seasonal space-heating energy efficiency in active mode (η_{son})	x,x	%
Part-load output at 30% P _{hs} (P ₁)	x,x	kW	Useful efficiency at minimum-part-load input (η_0)	x,x	%
Min part-load output at min pl input (P ₀)	x,x	kW	Useful efficiency at P _{hs} (η_4)	x,x	%
			Useful efficiency at 30% P _{hs} (η_1)	x,x	%
Turndown ratio	x,x	%	Heat loss in operating modes without heat demand (P _{h,l})	x,xxx	kW
Electricity consumption			Other		
Parameter	Value	Unit	Parameter	Value	Unit
Full-load auxiliary power consumption (elmax)	x,xxx	kW	Sound-power class indoors		A-E
			Sound-power class outdoors		A-E

Part-load auxiliary power consumption (elmin)	x,xxx	kW	Sound-power level (L _{WA}) indoors	x	dB(A)
			Sound-power level (L _{WA}) outdoors	x	dB(A)
Standby-mode power consumption (P _{SB})	x,xxxx	kW	NO _x emission value	x,x	mg/ kWh fuel input

(1) Based on the [2026/ xxx] (see footnote 10)

Table 7
Electric boiler heaters

Electric boiler heater					
Brand or trademark:		Model identifier:			
Space-heating energy-efficiency class ⁽¹⁾ :					
Energy-smart appliance: <input type="checkbox"/>			Combination heater: <input type="checkbox"/>		
Heat output			Space-heating efficiency		
Parameter	Value	Unit	Parameter	Value	Unit
Standard-rated heat output (P ₄)	x,x	kW	Seasonal space-heating efficiency (η _{s,h})	x,x	%
Electricity consumption			Other		
Parameter	Value	Unit	Parameter	Value	Unit
Standard-rated electric power input at P ₄ (EC)	x,x	kW	Sound-power class indoors		A-E
			Sound-power class outdoors		A-E
Standby-mode power consumption (P _{SB})	x,xxxx	kW	Sound-power level (L _{WA}) indoors	x	dB(A)
			Sound-power level (L _{WA}) outdoors	x	dB(A)

Based on [2026/ xxx] (see footnote 10)

Table 8
Cogeneration heaters

Cogeneration heater					
Brand or trademark:		Model identifier:			
Space-heating energy-efficiency class ⁽¹⁾ :					
Fuel type:		Gaseous fuel <input type="checkbox"/> Liquid fuel <input type="checkbox"/>		Combination heater: <input type="checkbox"/>	
If gaseous fuel:		Reference gas: G20 <input type="checkbox"/> G25 <input type="checkbox"/> G30 <input type="checkbox"/> G31 <input type="checkbox"/>			
Heat output and input			Space-heating efficiency		
Parameter	Value	Unit	Parameter	Value	Unit
Standard-rated heat output (P_4)	x,x	kW	Seasonal space-heating efficiency ($\eta_{s,h}$)	x,x	%
Standard-rated heat input (P_{hs})	x,x	kW	Seasonal space-heating efficiency in active mode (η_{son})	x,x	%
Electricity input and output			Others		
Parameter	Value	Unit	Parameter	Value	Unit
Full-load auxiliary power (e_{lmax})	x,xxx	kW	Sound-power class indoors		A-E
			Sound-power class indoors		A-E
Rated electric power output (P_{el})	x,x	kW	Sound-power level indoors (L_{WA})	x	dB(A)
			Sound-power level outdoors (L_{WA})	x	dB(A)
			NOx emission value	x,x	mg/kWh

(1) Based on the [2026/ xxx] (see footnote 10)

Table 9
Cogeneration heaters with backup boiler

Backup cogeneration heater	
Brand or trademark:	Model identifier:
Space-heating energy-efficiency class ⁽¹⁾ :	
Fuel type:	Gaseous fuel <input type="checkbox"/> Liquid fuel <input type="checkbox"/>
If gaseous	Reference gas: G20 <input type="checkbox"/> G25 <input type="checkbox"/> G30 <input type="checkbox"/> G31 <input type="checkbox"/>
Combination heater: <input type="checkbox"/>	

fuel:					
Heat output and input			Space-heating efficiency		
Parameter	Value	Unit	Parameter	Value	Unit
Standard-rated heat output (P_4)	x,x	kW	Seasonal space-heating efficiency ($\eta_{s,h}$)	x,x	%
Heat output of the cogeneration heater alone in a 30/50 temperature regime (P_{CHP})	x,x	kW	Seasonal space-heating efficiency in active mode (η_{son})	x,x	%
Standard-rated heat input (P_{hs})	x,x	kW	Efficiency at standard-rated heat output (η_4)	x,x	%
Heat input of the cogeneration heater alone in a 30/50 temperature regime (P_{input_CHP})	x,x	kW	Efficiency of the cogeneration heater alone in a 30/50 temperature regime (η_{CHP})	x,x	%
Electricity input and output			Efficiency at 30% of the standard-rated heat output in a 30/50 temperature regime (η_1)	x,x	%
Parameter	Value	Unit	Others		
Rated electric power output (P_{el})	x,x	kW	Parameter	Value	Unit
Rated electric power output in a 30/50 temperature regime (P_{el_CHP})	x,x	kW	Sound-power class outdoors		A-E
Full-load auxiliary power (el_{max})	x,xxx	kW	Sound-power level (L_{WA}) indoors	x	dB(A)
Others			Sound-power level (L_{WA}) outdoors	x	dB(A)
Sound-power class indoors		A-E	NOx emission value	x,x	mg/kWh

(1) Based on [2026/ xxx] (see footnote 10)

Table 10

Heat-pump heaters and hybrid heat-pump heaters (general information)

Heat pump and hybrid heat pump	
Brand or trademark	Model identifier:
Space-heating energy-efficiency class ⁽¹⁾ :	
Heater type	

Electric heat-pump heater <input type="checkbox"/> with physical electric backup <input type="checkbox"/> with virtual electric backup <input type="checkbox"/> Fuel heat-pump heater <input type="checkbox"/> with fuel backup heater <input type="checkbox"/> Hybrid heat-pump heater <input type="checkbox"/>					
Heat-pump heater / heat-pump heat-generator type by heat source: ventilation exhaust air <input type="checkbox"/> outdoor air <input type="checkbox"/> ground heat exchanger <input type="checkbox"/> ground direct exchange <input type="checkbox"/>			Cooling: none: <input type="checkbox"/> by reverse cycle: <input type="checkbox"/> by free cooling: <input type="checkbox"/> For use in space-cooling temperature applications: Low: <input type="checkbox"/> Medium: <input type="checkbox"/>		
<i>If fuel heat-pump heater / hybrid heat-pump heater comprising a heat-generator utilising fuel combustion for heat generation:</i> Fuel type: Gaseous fuel <input type="checkbox"/> Liquid fuel <input type="checkbox"/> <i>If gaseous fuel:</i> Reference gas: G20 <input type="checkbox"/> G25 <input type="checkbox"/> G30 <input type="checkbox"/> G31 <input type="checkbox"/>			Energy-smart appliance: <input type="checkbox"/>		
			F-gas free refrigerant: yes <input type="checkbox"/> no <input type="checkbox"/>		
			Combination heater: <input type="checkbox"/>		
Space-heating performances					
Parameter	Climate conditions	Value			Unit
		Temperature application			
		Low	Medium	High (optional)	
Condition in which the heat pump can work	Average	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
	Warmer	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
	Colder	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Seasonal space-heating energy efficiency ($\eta_{s,h}$)	Average	x,x	x,x	x,x	%
	Warmer	x,x	x,x	x,x	
	Colder	x,x	x,x	x,x	
Declared heat output (P_{dh})	Average	x,x	x,x	x,x	kW
	Warmer	x,x	x,x	x,x	
	Colder	x,x	x,x	x,x	
$P_{design,h}$	Average	x,x	x,x	x,x	kW
	Warmer	x,x	x,x	x,x	
	Colder	x,x	x,x	x,x	
Physical backup	Average	x,x	x,x	x,x	kW
	Warmer	x,x	x,x	x,x	
	Colder	x,x	x,x	x,x	
Virtual backup	Average	x,x	x,x	x,x	kW
	Warmer	x,x	x,x	x,x	
	Colder	x,x	x,x	x,x	
Other					
Parameter	Value	Unit	Parameter	Value	Unit
NO _x emissions value	x,x	(mg/kWh input)	Sound-power class indoors		A-E
			Sound-power class outdoors		A-E

			Sound-power level (L_{WA}) indoors	x	dB(A)
			Sound-power level (L_{WA}) indoors	x	dB(A)

(1) Based on [2026/ xxx] (see footnote 10)

Table 11

Heat-pump heaters and hybrid heat-pump heaters (Calculation of seasonal space-heating energy efficiency)

PART A										
Climate and temperature dependent parameters										
Climate: Average <input type="checkbox"/> Warmer <input type="checkbox"/> Colder <input type="checkbox"/> Temperature application: Low <input type="checkbox"/> Medium <input type="checkbox"/> High <input type="checkbox"/>										
Parameter	T_j	p_l	P_h	P_{dh}	COP_d	C_{dh}	P_{add}	$Input_{a,dd}$	AE_F	COP_{bin}
					FUE_d					FUE
Unit and decimal place accuracy	°C x	% x	kW x.x	kW x.x	(-) x.xx	(-) x.xx	kW x.x	kW x.x	kW x.x	(-) x.xx
Test conditions	Value									
A										
B										
C										
D										
E (T_{biv} or $T_{fb,off}$)										
F (TOL or $T_{hp,on}$)										
G (-15 °C, only if $TOL < -20$ °C, colder)										
Climate and temperature independent parameters										
Parameter	Value	Unit	Parameter	Val	Unit					

									ue	
Power in thermostat-off mode (P_{To})	x,xxxx	kW	Seasonal space-heating energy efficiency in active mode (η_{son})	x,x	%					
Power in standby mode (P_{SB})	x,xxxx	kW	additional annual auxiliary electricity consumption (Q_{aux})	x	kWh/a					
Power in crankcase mode (P_{CK})	x,xxxx	kW	annual heat demand (Q_H)	x	kWh/a					
Power in off mode (P_{OFF})	x,xxxx	kW	equivalent number of annual hours in active mode (H_{HE})	x	H					
seasonal auxiliary electricity factor (SAEF)	x,x	kW	annual heating energy consumed (Q_{HE})	x	kWh/a					
F(1)	x	%	seasonal coefficient of performance in active mode ($SCOP_{on}$)	x,x	(-)					
F(2)	x	%	seasonal fuel-utilisation efficiency (SFUE)	x,x	(-)					
F(3)	x	%	seasonal primary energy ratio (SPER)	x,x	(-)					
PART B										
Climate: Average <input type="checkbox"/> Warmer <input type="checkbox"/> Colder <input type="checkbox"/> Temperature application: Low <input type="checkbox"/> Medium <input type="checkbox"/> High <input type="checkbox"/>										
Parameter	COP_d	C_{dh}	P_{ad}	$Input_{ad}$	COP_{bin}	Positions of actuators, compressor(s) frequency of rotation in Hz or capacity stages, fan(s) frequency of rotation in Hz, circulator(s) frequency of rotation in Hz, depending on heat source of heat pump or hybrid heat pump, engine frequency of rotation in Hz.				
	FUE_d				FUE					
Unit and decimal place	(-) x.xx	(-) x.x	kW x.x	kW x.x	(-) x.xx	Hz x.x	Hz x.x	Hz x.x	Hz x.x	

accuracy		x							
Test conditions	Value								
A									
B									
C									
D									
E (T _{biv} or T _{fb,off})									
F (TOL or T _{hp,on})									
G (-15 °C, only if TOL < -20 °C, colder climate)									
Other information required to set up the unit									

Table 12

Heat-pump heaters and hybrid heat-pump heaters (3 – Cooling)

PART A			
Parameter	Value		Unit
	Temperature application		
	Low	Medium	
Seasonal space cooling energy efficiency ($\eta_{s,c}$)	x,x	x,x	%
Design load for cooling ($P_{designc}$)	x,x	x,x	kW
Climate and temperature dependent parameters			

Climate conditions: Average <input type="checkbox"/> Warmer <input type="checkbox"/> Colder <input type="checkbox"/> Temperature application: Low <input type="checkbox"/> Medium <input type="checkbox"/> High <input type="checkbox"/>															
Parameter	T _j	p _l			P _c		P _{dc}		EER _d FUEC _d		EER _{bin} FUEC _{bin}		C _{dc}		
Unit and decimal place accuracy	°C x	%			kW x.x		kW x.x		(-) x.xx		(-) x.xx		(-) x.xx		
Test conditions	Value														
A															
B															
C															
D															
Climate and temperature independent parameters															
Parameter					Value		Unit		Parameter			Value		Unit	
Power in thermostat-off mode (P _{TO})					x,xxxx		kW		F(3)			x		%	
Power in standby mode (P _{SB})					x,xxxx		kW		additional annual auxiliary electricity consumption (Q _{aux})			x		kW/a	
Power in crankcase mode (P _{CK})					x,xxxx		kW		annual cooling demand (Q _c)			x		kWh	
Power in off mode (P _{OFF})					x,xxxx		kW		equivalent number of annual hours in active mode (H _{CE})			x		H	
seasonal auxiliary electricity factor (SAEF _c)					x,x		kW		annual heating energy consumed (Q _{CE})			x		kWh/a	
F(1)					x		%		SEER _{on}			x,x		(-)	
F(2)					x		%		seasonal fuel-utilisation efficiency (SFUE _c)			x,x		(-)	
PART B															
Climate: Average <input type="checkbox"/> Warmer <input type="checkbox"/> Colder <input type="checkbox"/> Temperature application: Low <input type="checkbox"/> Medium <input type="checkbox"/>															
Parameter	Compressor(s) frequency of rotation in Hz or capacity stages				Outdoor fan(s) frequency			Condenser flow			Evaporator flow				

Unit	Hz	Hz	m ³ /h	m ³ /h
Test conditions	Value			
A	x	x	x,xx	x,xx
B	x	x	x,xx	x,xx
C	x	x	x,xx	x,xx
D	x	x	x,xx	x,xx
Other information required to set up the unit				

Table 13
Water heating parameters

Water-heating efficiency					
Parameter	Value	Unit	Parameter	Value	Unit
Load profile		S-4XL	Water-heating efficiency (η_{wh})	x,x	%
Electricity consumption for water heating (Q_{elec})	x	kWh	Water-heating energy-efficiency class ⁽¹⁾		A-E
Fuel consumption for water heating (Q_{fuel})	x	kWh	Mixed water at 40 °C (V40)	x,x	L
Adaptive control: <input type="checkbox"/>					
<i>If adaptive control, fill in the part below</i>					
Parameter	Value	Unit	Parameter	Value	Unit
Weekly electricity consumption for water heating ($Q_{elec,week}$)	x,x	kWh	Weekly electricity consumption for water heating with adaptive control enabled ($Q_{elec,week,adaptive}$)	x,x	kWh
Weekly fuel consumption for water heating ($Q_{fuel,week}$)	x,x	kWh	Weekly fuel consumption for water heating with adaptive control enabled ($Q_{fuel,week,adaptive}$)	x,x	kWh

Off-peak combination heater: <input type="checkbox"/>					
<i>If off-peak combination heater, fill in the part below</i>					
Load profile in off-peak applications		S-4XL	Water-heating efficiency (η_{wh}) in off-peak applications	x,x	%
			Mixed water at 40 °C (V40) in off-peak applications	x,x	L

(1) Based on [2026/ xxx] (see footnote 10)

Table 14
Temperature controls

Temperature control					
Brand or trademark:		Model identifier:			
Parameter	Value	Unit	Parameter	Value	Unit
Class of the temperature control		I - VIII	Contribution of the temperature control to seasonal space-heating energy efficiency		% points

Table 15
Solar devices

Solar device									
Brand or trademark:			Model identifier:						
Solar-device factor for space heating									
Climate	Number of solar collectors ***	Gross area of collector array*** [m²]	Annual heating demand****						
			Q _H [kWh]	X	X	X	X	X	[...]
			P ^{design} _h [kW]	X,X	X,X	X,X	X,X	X,X	[...]
			P ₄ [kW]	X,X	X,X	X,X	X,X	X,X	[...]
	X	X,X		Solar-device factor for space heating (per climate, collector surface and annual heating demand, in % points)*, ****					

Average				X,X	X,X	X,X	X,X	X,X	[...]
Warmer				X,X	X,X	X,X	X,X	X,X	[...]
Colder				X,X	X,X	X,X	X,X	X,X	[...]
Average	x	x,x		X,X	X,X	X,X	X,X	X,X	[...]
Warmer				X,X	X,X	X,X	X,X	X,X	[...]
Colder				X,X	X,X	X,X	X,X	X,X	[...]
[...]	[...]	[...]		[...]	[...]	[...]	[...]	[...]	[...]
Solar-device factor for water heating									
Climate	Number of solar collectors	Gross area of collector array [m ²]	Load profile of combination heater included in the package						
			M	L	XL	XXL	3XL	4XL	
			Solar-device factor for water heating (per climate, chosen collector surface and load profile, in % points)**						
Average	x	x,x	X,X	X,X	X,X	X,X	X,X	X,X	X,X
Warmer			X,X	X,X	X,X	X,X	X,X	X,X	X,X
Colder			[...]**	X,X	X,X	X,X	X,X	X,X	X,X

* Not less than 100% and not more than 300%.

** Not less than 100% and not more than 240% for colder climate conditions, 450% for average climate conditions and 500 % for warmer climate conditions.

*** Additional cells with corresponding values can be included based on the number of solar collectors and the gross collector area. The " [...]" notation signifies that the table may be extended, following the structure of the referenced table.

**** All provided values are subject to potential modifications or adjustments, as necessary, depending on specific declarations made by the manufacturer.

***** The " [...]" notation also indicates that the table may be extended with additional rows below depending on the manufacturer's declarations.

Table 16
Devices for recovering heat from shower water

Shower-water heat-recovery device	
Brand or trademark:	Model identifier:

Load profile of combination heater included in the package	XS	S	M	L	XL	XXL	3XL	4XL
Shower-water heat-recovery-device factor $f_{\text{SWHRD},lp}$, in %	x,x	x,x	x,x	x,x	x,x	x,x	x,x	x,x
Shower-water heat-recovery-device efficiency $\eta_{\text{SWHRD},lp}$, in %	x,x	x,x	x,x	x,x	x,x	x,x	x,x	x,x
$\eta_{12,5}$, in %	x,x	x,x	x,x	x,x	x,x	x,x	x,x	x,x
η_i , in %	x,x	x,x	x,x	x,x	x,x	x,x	x,x	x,x
$q_{v,i}$, in L/min	x,x	x,x	x,x	x,x	x,x	x,x	x,x	x,x

Table 17
Packages

Package					
Brand or trademark:					
Model identifier:					
Package parameters					
For use in temperature application: Low <input type="checkbox"/> Medium <input type="checkbox"/> High			For use in climate conditions: Average <input type="checkbox"/> Warmer <input type="checkbox"/> Colder <input type="checkbox"/>		
Space heating			<i>If package includes combination heater</i> Water heating		
Parameter	Value	Unit	Parameter	Value	Unit
Seasonal space-heating energy efficiency	x,x	%	Water-heating energy efficiency	x,x	%
Standard-rated heat output for space heating	x,x	kW	Load profile		S-4XL
Space heating energy efficiency class ⁽¹⁾		A-G	Water heating energy efficiency class ⁽¹⁾		A-G
Package elements					
Heater included in the package					
Type of heater:			Space heating		

Fuel boiler heater <input type="checkbox"/>	Parameter	Value	Unit
Electric boiler heater <input type="checkbox"/>			
Hybrid boiler heater <input type="checkbox"/>			
Cogeneration heater <input type="checkbox"/>			
Hybrid cogeneration heater <input type="checkbox"/>			
Electric heat-pump heater <input type="checkbox"/>			
Fuel heat-pump heater <input type="checkbox"/>			
Hybrid heat-pump heater <input type="checkbox"/>	<i>If combination heater</i> Water heating		
Combination heater <input type="checkbox"/>	Parameter	Value	Unit
Reversible heat-pump heater <input type="checkbox"/>	Water-heating energy efficiency	x,x	%
Free cooling <input type="checkbox"/>	Water heating energy efficiency class ⁽¹⁾		A-G
<i>If reversible heat-pump heater</i> Space cooling			
Parameter	Value		Unit
	Temperature application		
	Low	Medium	
Seasonal space-cooling energy efficiency ($\eta_{s,c}$)	x,x	x,x	%
Design load for cooling ($P_{designc}$)	x,x	x,x	kW
Link to heater model included in the package:	https://eprel.ec.europa.eu/qr/EPREL identifier		
Other elements of the package			
Temperature control <input type="checkbox"/>	Parameter	Value	Unit
Number of products in the package:	Temperature-control class		A-G
	Contribution factor to $\eta_{s,h}$ of the package (TC)	x	% points
Link to temperature control model included in the package:	https://eprel.ec.europa.eu/qr/EPREL identifier		

Solar device <input type="checkbox"/>	Parameter	Value	Unit
Number of products in the package:	Solar-device factor for space heating	x,x	% points
	Solar-device factor for water heating	x,x	% points
Link to solar device model included in the package:		https://eprel.ec.europa.eu/qr/EPREL identifier	
Link to product database for the solar-device model included in the package:			
Shower-water heat-recovery device <input type="checkbox"/>	Parameter	Value	Unit
Number of products in the package:	Shower-water heat-recovery-device factor	x,x	% points
Link to solar device model included in the package:		https://eprel.ec.europa.eu/qr/EPREL identifier	

(1) Based on [2026/ xxx] (see footnote 10)

Table 18
Energy smart appliances

Energy-smart appliances	
Part A – Product-information sheet	
Brand or trademark:	Model identifier:
Appliance compliant with the EU Code of Conduct for the interoperability of energy-smart appliances	<input type="checkbox"/> Appliance compliant
How does the appliance achieve compliance with the Code of Conduct? ⁽¹¹⁾	<input type="checkbox"/> Dongle/adaptor <input type="checkbox"/> Cloud connection <input type="checkbox"/> Built in the appliance
Which use cases does the appliance implement? ⁽¹²⁾	<input type="checkbox"/> Flexible start <input type="checkbox"/> Power-consumption monitoring <input type="checkbox"/> Power-consumption limitation

⁽¹¹⁾ Only one can be selected.

⁽¹²⁾ More than one option can be selected.

	<input type="checkbox"/> Incentive table-based power-consumption management <input type="checkbox"/> Manual operation <input type="checkbox"/> Future use cases ⁽¹³⁾
Manufacturer's link to free access website with end-user information	
Part B – Technical documentation	
Communication protocol used to implement the use cases:	<input type="checkbox"/> SPINE <input type="checkbox"/> SPINE IoT <input type="checkbox"/> Matter <input type="checkbox"/> Home Connectivity Alliance <input type="checkbox"/> S2 <input type="checkbox"/> Others (please specify) [_...._]

10. REQUIREMENTS RELATED TO SELF-MONITORING

10.1. Scope of the self-monitoring requirements

Requirements set out in this section shall apply to heaters with a standard-rated heat output of 70 kW or less.

10.2. General requirements

Depending on its type, the heater shall determine, store and display:

- (a) the energy input to the heater (electricity, gaseous or liquid fuels); in case several types of energy sources are used by the unit, energy input for each and all energy sources shall be determined;
- (b) the thermal energy output, meaning space heating for all heaters and also space cooling for reversible heaters; the thermal energy output shall be measured;
- (c) for cogeneration heaters and cogeneration heater with backup boiler, electrical energy output;
- (d) the energy efficiency (the ratio of thermal energy output and electrical energy output to energy input); in order to calculate it, electricity must be converted to primary energy with a CC equal to 1,9 for consumed electricity and a coefficient of 2,65 for cogenerated electricity and using fuel gross calorific value (GCV).
- (e) number of on/off cycles (number of periods for which the heater has been stopped by the thermostat) and
- (f) for combination heaters, whether the heater is used for space heating or sanitary water heating.

10.3. Requirements related to data display

1. Instantaneous values shall be displayed at a sample rate of a maximum of 1 minute.
2. The display option shall be available from the main menu of the end-user interface.

⁽¹³⁾ Future use cases can be considered when the Code of Conduct is updated, as new versions will integrate evolving solutions and protocols to address emerging needs.

3. Instantaneous and average data referred to in point 10.4 shall be displayed on the display of the heater or remotely (for example by means of a computer application, mobile application, website, or dedicated separate display).

10.4. Requirement related to data storage

1. The values mentioned in point 10.2 shall be stored with the following frequency: instantaneous values for two days, average values of any hour, day, week, month and year, covering the period of at least the previous 24 months or the period since the heater installation, whichever period is shorter.
2. For heaters which allow for communication with a building automation and control system, data referred to in this point can be stored in the building automation and control system.
3. Data stored in accordance with this point shall be accessible to end-user or third parties by means of a standard interface, such as for example USB port, SD-card or Wi-Fi connection, in machine-readable format (such as for example a csv or xml file), without undue delay.

ANNEX III

Measurements and calculations

1. INTRODUCTION

For the purposes of verification of conformity and of compliance with the requirements of this Regulation, measurements and calculations shall be made using harmonised standards the reference numbers of which have been published for this purpose in the Official Journal of the European Union, or using other reliable, accurate and reproducible methods that consider the generally recognised state-of-the-art methods and are in conformity with the provisions of this Annex and Annex IV.

Measurements and calculations should be performed using the data provided in accordance with Annex II and additional data required in accordance with this Annex. Where a parameter is declared as part of the technical documentation, its declared value shall be used by the manufacturer, importer, or authorised representative for the calculations in this Annex.

2. CALCULATION OF SEASONAL SPACE-HEATING ENERGY EFFICIENCY ($\eta_{s,h}$)

2.1. Fuel boiler heaters, electric boiler heaters and cogeneration heaters

The seasonal space-heating efficiency $\eta_{s,h}$, expressed in %, for fuel boiler heaters, electric boiler heaters and cogeneration space-heaters shall be calculated in the following way:

$$\eta_{s,h} = \eta_{son} \times \left(1 - \frac{\sum F(i)}{100\%} \right)$$

where:

- η_{son} is the seasonal space-heating energy efficiency in active mode, calculated in Annex III, Section 4 hereafter;
- $\sum F(i)$ is the sum of the values of correction factors for controls, auxiliary energy and standby heat loss, calculated and applied in accordance with Annex III, Section 5 hereafter.

2.2. Electric heat-pump heaters and hybrid heat-pump heaters

- (a) The seasonal space-heating efficiency $\eta_{s,h}$, expressed in %, for electric heat-pump heaters shall be calculated in the following way:

$$\eta_{s,h} = \frac{1}{CC} \times SCOP \times \left(1 - \frac{\sum F(i)}{100\%} \right)$$

where:

- CC is the conversion coefficient;
- $\sum F(i)$ is the sum of the values of correction factors for controls and auxiliary energy, calculated in Annex III, Section 5;
- SCOP is the seasonal coefficient of performance, calculated in accordance with point (b).

- (b) The seasonal coefficient of performance (SCOP) shall be calculated in the following way:

$$SCOP = \frac{Q_H}{Q_{HE}}$$

where:

- Q_H is the annual heat demand (in kWh/a), calculated in accordance with point (c);
- Q_{HE} is the annual heating energy consumed (in kWh/a), calculated in accordance with point (d).

(c) The annual heating demand (Q_H) shall be calculated in the following way:

$$Q_H = P_{designh} \times H_{HE}$$

where:

- $P_{designh}$ is the design heat load (in kW), in the reference design conditions set out in Table 1;
- H_{HE} is the equivalent number of annual hours in active mode, set out in Table 2.

(d) The annual heating energy consumed (Q_{HE}) shall be calculated in the following way:

$$Q_{HE} = \frac{Q_H}{SCOP_{on}} + Q_{aux}$$

where:

- Q_H is the annual heat demand (in kWh/a), calculated in the accordance with point (c);
- $SCOP_{on}$ is the active mode coefficient of performance, calculated in Annex III, Section 4.5;
- Q_{aux} is the additional annual auxiliary electricity consumption, in kWh/a, calculated in accordance with point (e).

(e) The additional annual auxiliary electricity consumption shall be calculated in the following way:

$$Q_{aux} = H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}$$

where:

- H_{TO} are the annual hours in thermostat-off mode, indicated in Table 2;
- H_{SB} are the annual hours in standby mode, indicated in Table 2;
- H_{CK} are the annual hours in crankcase mode, indicated in Table 2;
- H_{OFF} are the annual hours in off mode, indicated in Table 2;
- P_{TO} is the measured power in thermostat-off mode;
- P_{SB} is the measured power in standby mode;
- P_{CK} is the measured power in crankcase mode;
- P_{OFF} is the measured power in off mode.

2.3. Fuel heat-pump heaters

- (a) The seasonal space-heating efficiency $\eta_{s,h}$ expressed in %, shall be calculated in the following way:

$$\eta_{s,h} = SPER \times \left(1 - \frac{\Sigma F(i)}{100\%}\right)$$

where:

- $\Sigma F(i)$ is the sum of the values of correction factors for controls and auxiliary energy, calculated in Annex III, Section 5;
- SPER is the seasonal primary energy ratio, calculated in the following way:

$$SPER = \frac{1}{\frac{1}{SFUE} + \frac{CC}{SAEF}}$$

where:

- $SFUE$ is the seasonal fuel-utilisation efficiency in active mode, calculated in accordance with point 4.6.(c);
- $SAEF$ is the seasonal auxiliary electricity factor, calculated in accordance with point (b);

- (b) The seasonal auxiliary electricity factor (SAEF) shall be calculated in the following way:

$$SAEF = \frac{Q_H}{Q_{HElec}}$$

where:

- Q_H is the annual heat demand (in kWh/a), calculated in accordance with point (c);
- Q_{HElec} is the annual electricity consumption (in kWh/a), calculated in accordance with point (d);

- (c) The annual heating demand (Q_H) shall be calculated in the following way:

$$Q_H = P_{designh} \times H_{HE}$$

where:

- $P_{designh}$ is the design heat load (in kW), at the reference design conditions set out in Table 1;
- H_{HE} is equivalent number of annual hours in active mode, set out in Table 2;

- (d) The annual electricity consumption (Q_{HElec}) shall be calculated in the following way:

$$Q_{HElec} = \frac{Q_H}{SAEF_{on}} + Q_{aux}$$

where:

- Q_H is the annual heat demand (in kWh/a), calculated in the accordance with point (c);
- $SAEF_{on}$ is the active mode coefficient of performance, calculated in accordance with Annex III, Section 4.5;

- Q_{aux} is the additional annual auxiliary electricity consumption, in kWh/a, calculated in accordance with point (e);
- (e) The additional annual auxiliary electricity consumption shall be calculated in the following way:

$$Q_{aux} = H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}$$

where:

- HTO are the annual hours in thermostat off mode, indicated in Table 2;
- HSB are the annual hours in standby mode, indicated in Table 2;
- HCK are the annual hours in crankcase mode, indicated in Table 2;
- HOFF are the annual hours in off mode, indicated in Table 2;
- PTO is the measured power in thermostat off mode;
- PSB is the measured power in standby mode;
- PCK is the measured power in crankcase mode;
- POFF is the measured power in off mode.

Table 1

Heating and cooling outdoor air temperature reference design conditions for reversible heaters, temperatures in dry bulb air temperature (wet bulb air temperature indicated in brackets)

<i>Climate</i>		<i>Average</i>	<i>Warmer</i>	<i>Colder</i>
Reference design conditions for cooling				
Cooling reference design temperature	$T_{designc}$	+ 35 °C	N/A	N/A
For heat-pump heaters and hybrid heat-pump heaters using ventilation exhaust air for cooling, maximum ventilation exhaust air flow rate for space cooling in m ³ /h at 27 (19) °C with $P_{designh}$ expressed in kW,	$q_{v,maxc}$	maximum $2.5 * P_{designc} / 0.01 \text{ m}^3/\text{h}$	N/A	N/A
Reference design conditions for heating				
Heating reference design temperature	$T_{designh}$	-10 °C	+ 2 (+1) °C	-22 °C
Bivalent temperature for electric heat-pump heaters (Maximum value)	T_{biv}	+ 2 °C	+ 2 °C	-7 (-8) °C
Temperature operation limit for heat-pump heaters (Maximum value)	TOL	-7 (-8) °C	+2 °C	-15 °C
For heat-pump heaters and	$q_{v,maxh}$	maximum		

hybrid heat-pump heaters using ventilation exhaust air, maximum ventilation exhaust air flow rate for space-heating in m ³ /h at 20 (15) °C with $P_{designh}$ expressed in kW,		$P_{designh} / 0,01 \text{ m}^3/\text{h}$
--	--	---

Table 2

Heat-pump heater number of hours used (h/a)

Climate	Cooling function	Heating or cooling	Mode				
			Active	Thermostat -off	Standby	Off	Crankcase heater
			H _{HE} / H _{CE}	H _{TO}	H _{SB}	H _{OFF}	H _{CK}
Average	Heating only	Heating	2066	178	0	3672	3850
	Reversible	Heating	2066	178	0	0	178
	Reversible (P _{SR,c} ≤ 12 kW)	Cooling	350	221	2142	0	2363
	Reversible (P _{SR,c} > 12 kW)	Cooling	600	659	1377	0	2036
Warmer	Heating only	Heating	1336	754	0	4416	5170
	Reversible	Heating	1336	754	0	0	754
Colder	Heating only	Heating	2465	106	0	2208	2314
	Reversible	Heating	2465	106	0	0	106

3. CALCULATION OF PARAMETERS FOR ACTIVE MODE: SEASONAL SPACE-HEATING ENERGY EFFICIENCY IN ACTIVE MODE (η_{son}), SEASONAL AUXILIARY ELECTRICITY FACTOR IN ACTIVE MODE (SAEF_{on}) AND SEASONAL FUEL-UTILISATION FACTOR (SFUE)

3.1. Fuel boiler heaters

The seasonal space-heating efficiency η_{son} , expressed in %, for the fuel boiler heaters, shall be calculated in the following way:

$$\eta_{son} = 0.85 \times \eta_1 + 0.15 \times \eta_4,$$

where:

- η_1 is the efficiency at 30 % of the standard-rated heat input P_{hs} ;
- η_4 is the efficiency at standard-rated heat input P_{hs} .

3.2. Electric boiler heaters

The seasonal space-heating efficiency η_{son} , expressed in %, for the fuel boiler heaters, shall be calculated in the following way:

$$\eta_{son} = \eta_4,$$

where η_4 is the useful efficiency at standard-rated heat output P_4 , calculated in the following way:

$$\eta_4 = \frac{P_4}{EC \times CC}$$

where:

- P_4 is the standard-rated heat output expressed in kW;
- EC is the electric power consumption to produce the standard-rated heat output P_4 ;
- CC is the conversion coefficient.

3.3. Cogeneration space heaters

The seasonal space-heating efficiency η_{son} , expressed in %, for cogeneration heaters, shall be calculated in the following way:

$$\eta_{son} = \frac{P_4 + 2.65 \times P_{el}}{P_{hs}},$$

where:

- P_4 is the standard-rated heat output expressed in kW;
- P_{el} is the standard-rated electric power output expressed in kW;
- P_{hs} is the standard-rated heat input in GCV of the fuel input in kW.

3.4. Cogeneration space heater with fuel backup heater

(a) The seasonal space-heating efficiency η_{son} , expressed in %, for cogeneration heater with fuel backup heater, shall be calculated in the following way:

$$\eta_{son} = 0.85 \times \eta_1 + 0.15 \times \eta_4,$$

where:

- η_1 is the efficiency at 30 % of the standard-rated heat output P_4 , calculated in accordance with point (b);
- η_4 is the efficiency at standard-rated heat output P_4 ;

(b) η_1 shall be calculated in the following way:

- (i) For a cogeneration heater with fuel backup heater, for which the maximum output of the cogeneration heat generator in 30/50 temperature regime is equal to or higher than 30 % of P_4 :

$$\eta_1 = \eta_{CHP} = \frac{P_{CHP} + 2.65 \times P_{el_CHP}}{P_{input_CHP}},$$

where:

- η_{CHP} is the efficiency of the cogeneration heater alone in 30/50 temperature regime;
- P_{CHP} is the heat output, when only the cogeneration heat generator is supplying heat, in a 30/50 temperature regime, expressed in kW;
- P_{el_CHP} is the rated electric power output, when only the cogeneration heat generator is supplying heat, in a 30/50 temperature regime, expressed in kW;
- P_{input_CHP} is the heat input power in GCV of the liquid fuel or gaseous fuel input of the cogeneration, when only the cogeneration heat generator is supplying heat, in a 30/50 temperature regime, expressed in kW.

- (ii) For a cogeneration heater with a fuel backup heater, for which the maximum output of the cogeneration heat generator in a 30/50 temperature regime is lower than 30 % of P_4 :

$$\eta_1 = \frac{0.3}{\frac{P_{CHP} \times \alpha}{P_4 \times \eta_{CHP}} + \frac{(1 - \alpha)}{\eta_4}}$$

where α is the proportion of the time the cogeneration heat generator is supplying heat alone in order to reach 30 % of the standard-rated heat output, in a 30/50 temperature regime, calculated as follows:

$$\alpha = \frac{1 - 0.3}{1 - \frac{P_{CHP}}{P_4}}$$

3.5. Electric heat-pump heaters and hybrid heat-pump heaters

- (a) The active-mode seasonal coefficient of performance $SCOP_{on}$ is calculated in the following way:

$$SCOP_{on} = \frac{\sum_{j=1}^n h_j \times P_h(T_j)}{\sum_{j=1}^n h_j \left[\frac{P_h(T_j) - P_{add}(T_j)}{COP_{bin}(T_j)} + Input_{add}(T_j) \right]}$$

where:

- h_j is frequency of outdoor temperature in the temperature bin j , expressed in hours;
- $P_h(T_j)$ is the part-load for heating, calculated in accordance with point (b);
- $P_{add}(T_j)$ is the additional heat output required to be supplied by the backup heater, when the electric heat-pump heater is not able to supply $P_h(T_j)$ on its own, calculated in accordance with point (c);
- $Input_{add}(T_j)$ is the additional energy input consumed by the backup heater, calculated in accordance with point (d);
- $COP_{bin}(T_j)$ is the bin-specific coefficient of performance, calculated in accordance with point (e).

- (b) The part-load for heating $P_h(T_j)$ shall be calculated as follows:

$$P_h(T_j) = P_{design,h} \times pl(T_j)$$

where:

- $P_{design,h}$ is the design load;
- $pl(T_j)$ is the part-load ratio.

- (c) The additional heat output ($P_{add}(T_j)$) shall be calculated in the following way:

- (i) for heat-pump heaters without backup heater it is equal to 0;
- (ii) for electric heat-pumps with electric backup heater, it is the power output of the electric backup heater:

$$P_{add}(T_j) = elbu(T_j)$$

- (ii) for hybrid heat-pump heaters, it is the heat output of the fuel backup heater:

$$P_{add}(T_j) = \text{fuelbu}(T_j)$$

(d) The additional final energy input ($\text{Input}_{add}(T_j)$) shall be calculated in the following way:

- (i) for heat-pump heaters it is equal to 0;
- (ii) for electric heat-pump heater with electric backup heater, it is the power input to the electric backup heater and is equal to the heat output of the backup heater supposing a heating efficiency of 1 for the electric backup heater:

$$P_{add}(T_j) = \text{elbu}(T_j)$$

- (ii) for hybrid heat-pump heaters, it is the heat input to the fuel backup heater:

$$\text{Input}_{add}(T_j) = \frac{\text{fuelbu}(T_j)}{\eta_{s,h,\text{fuelbu}} \times \frac{1}{cc}} \times (1 - F(1)),$$

where:

- $\text{fuelbu}(T_j)$ is the bin-specific heat output of the fuel backup heater;
- $\eta_{s,h,\text{fuelbu}}$ is the seasonal space-heating efficiency of the fuel backup heater;
- $F(1)$ is the control correction factor defined in Section 5.1.

(e) Declared values for $\text{COP}_d(T_j)$ and $P_{dh}(T_j)$ are the measured values at the part-load test conditions for outdoor temperatures T_j ('bins') A to G and $P_{\text{design},h}$, as indicated in Table 3. The values for $\text{COP}_{bin}(T_j)$ shall be determined through interpolation and extrapolation of known values. If the heat-pump capacity is higher than the heat demand in a bin by more than 10 %, the heat-pump will cycle on/off and a degradation factor (C_{dh}) and a capacity ratio (CR) have to be used to calculate the COP_{bin} for T_j in the following way:

$$\text{COP}_{bin} = \frac{\text{COP}_d \times CR}{C_{dh} \times CR + (1 - C_{dh})}$$

where:

- CR is the capacity ratio, calculated in accordance with point (f);
- C_{dh} is the degradation coefficient for cycling behaviour; it is either 0.9 by default or it can be determined by a series of cyclic tests; it is then calculated as the ratio between the power during the off phase divided by the power during the on phase.

For cycling, the water temperature regime in the on phase is modified to maintain the same average water-temperature regime over the whole on/off cycle as in the stationary condition without cycling.

(f) The capacity ratio CR for the purposes of point (e) is calculated in the following way:

$$CR = pl(T_j) \times \frac{P_{\text{design},h}}{P_{dh}}$$

where:

- $Pl(T_j)$ is the part-load ratio;
- $P_{\text{design},h}$ is the design load;

- P_{dh} is the minimum capacity for heating in continuous operation.

(g) Test method for hybrid heat pumps

- The seasonal space-heating energy efficiency ($\eta_{s,h}$) of hybrid heat-pump heaters may be determined by testing the heating capacity and the efficiencies of the two heat generators (fuel boiler, electric heat-pump) separately, as long as this separate method does not deviate significantly from the results obtained with the joint method, in which the two heat generators are both working at the various test points according to the hybrid controller.
- For a separate determination, the tests for the heat-pump part of the hybrid heat-pump heater shall be conducted with only the heat-pump in operation and the other heat generator comprising the hybrid heat-pump heater hydraulically connected, for part-load conditions set out in Table 3 of this Annex, for outdoor temperature conditions greater or equal to $T_{hp,on}$.
- For a joint approach of hybrid heat-pump heaters:
 - (i) the seasonal performance is calculated using a method similar to the one used for heat-pumps alone;
 - (ii) the hybrid heater is tested at the various temperature and load conditions required for the specific climate and temperature level application; electricity consumption and fuel consumption are registered separately;
 - (iii) the calculation of $\eta_{s,h}$ is based on the interpolation at each bin temperature of the heating capacity and energy input of the hybrid unit between values at the tested part-load conditions.

3.6. Seasonal auxiliary electricity factor in active mode (SAEF_{on}) and seasonal fuel utilisation factor (SFUE) for fuel heat-pump heaters

- (a) The seasonal auxiliary electricity factor in active mode (SAEF_{on}) shall be calculated in the following way:

$$SAEF_{on} = \frac{\sum_{j=1}^n h_j \times P_h(T_j)}{\sum_{j=1}^n h_j \left[\frac{P_h(T_j)}{AEF(T_j)} \right]}$$

where:

- h_j is frequency of outdoor temperature in the temperature bin j , expressed in hours;
- $P_h(T_j)$ is the part load for heating, calculated in accordance with point (b);
- $AEF(T_j)$ is the ratio between the part load $P_h(T_j)$ and the electric power input at a specific outdoor temperature T_j , expressed in kW/kW.

- (b) The part load for heating $P_h(T_j)$ shall be calculated as follows:

$$P_h(T_j) = \frac{P_{design,h}}{pl(T_j)}$$

Where:

- $P_{design,h}$ is the design load;
- $pl(T_j)$ is the part load ratio.

- (c) The seasonal fuel-utilisation efficiency (SFUE) shall be calculated as follows:

$$SFUE = \frac{\sum_{j=1}^n h_j \times P_h(T_j)}{\sum_{j=1}^n h_j \left[\left(\frac{P_h(T_j)}{FUE(T_j)} - P_{add}(T_j) \right) + Input_{add}(T_j) \right]}$$

where:

- h_j is frequency of outdoor temperature in the temperature bin j , expressed in hours;
- $P_h(T_j)$ is the part load for heating, calculated in accordance with point (d);
- $FUE(T_j)$ is the ratio between the part load $P_h(T_j)$ and the measured thermal input in GCV at a specific outdoor temperature T_j , expressed in kW/kW;
- $P_{add}(T_j)$ is the additional heat output required to be supplied by the backup heater, when the fuel heat-pump is not able to supply $P_h(T_j)$ on its own, calculated in accordance with point (d);
- $Input_{add}(T_j)$ is the additional energy input consumed by the backup heater, calculated in accordance with point (e).

- (d) The additional heat output $P_{add}(T_j)$ shall be calculated in the following way:

- (i) if there is no backup, it is equal to 0;
- (ii) for fuel heat pumps with fuel backup heater:

$$P_{add}(T_j) = fuelbu(T_j)$$

- (e) The additional final energy input ($Input_{add}(T_j)$) shall be calculated in the following way:

- (i) if there is no backup, it is equal to 0;
- (ii) for fuel heat pumps with fuel backup heater:

$$Input_{add}(T_j) = \frac{fuelbu(T_j)}{\eta_{s,h_fuelbu}} \times (1 - F(1)),$$

where:

- $P_{sup}(T_j)$ is the bin-specific heat output of the fuel backup heater;
- η_{s,h_fuelbu} is the seasonal space-heating efficiency of the fuel backup heater;
- $F(1)$ is the control correction factor defined in Section 5.1.

- (f) Declared values for $FUE_d(T_j)$ and $P_{dh}(T_j)$ are the measured values under the part-load test conditions for outdoor temperatures T_j ('bins') A to F and $P_{designh}$, as indicated in Table 3. The values for $FUE(T_j)$ shall be determined through interpolation and extrapolation of known values. If the heat-pump capacity in a bin is too high for the heat demand in the bin by more than 10%, the heat pump will cycle on/off and a degradation factor (C_{dh}) and a capacity ratio (CR) has to be used to calculate the FUE for T_j in the following way:

$$FUE_{bin}(T_j) = \frac{FUE(T_j) \times CR}{C_{dh} \times CR + (1 - C_{dh})}$$

where:

- FUE(T_j) is the declared coefficient of performance, calculated in accordance with point (f) above;
- CR is the capacity ratio, calculated in accordance with point (f);
- C_{dh} is the degradation coefficient for cycling behaviour; either a default value can be used or the degradation coefficient can result from cyclic tests.

In case of cycling, the stationary water temperature regime is modified to maintain the same time-average water-temperature regime over the whole on/off cycle.

- (g) The capacity ratio CR for the purposes of point (e) is calculated in the following way:

$$CR = pl(T_j) \times \frac{P_{designh}}{P_{dh}}$$

where:

- $Pl(T_j)$ is the part-load ratio;
- $P_{designh}$ is the design load;
- P_{dh} is the minimum capacity for heating in continuous operation.

Table 3

Part-load test conditions for heat-pump heaters

Test #	Part-load ratio			Outdoor air**** * Inlet dry (wet) bulb °C	Indoor application	Variable outlet temperature °C			Mean temperature* °C		
	A %	W %	C %			A °C	W °C	C °C	A °C	W °C	C °C
A	88	n.a.	61	-7(-8)	LT	**/34	n.a.	**/30	31.3	n.a.	27.2
					MT	**/52	n.a.	**/44	47.8	n.a.	39.7
					HT	**/61	n.a.	**/50	55.8	n.a.	44.7
B	54	100	37	2(1)	LT	**/30	**/35	**/27	27.2	32.3	24.0
					MT	**/42	**/55	**/37	37.7	50.8	32.6
					HT	**/49	**/65	**/41	43.6	59.8	35.5
C	35	64	24	7(6)	LT	**/27	**/31	**/25	24.0	28.2	22.9
					MT	**/36	**/46	**/32	31.5	41.8	27.3
					HT	**/41	**/53	**/36	35.5	47.7	30.2
D	15	29	11	12(11)	LT	**/24	**/26	**/24	21.9	22.8	21.3
					MT	**/34	**/34	**/28	25.0	29.4	23.2

				HT	0 **/3 2	**/39	**/30	25.6	33.4	24.2
E *** *	var	var	var	TOL	all	***/ ***	***/ ***	***/ ***	***/ ***	***/ ***
F *** *	var	var	var	T _{biv}	all	***/ ***	***/ ***	***/ ***	***/ ***	***/ ***
G	n.a.	n.a.	82	-15	LT MT HT	n.a. n.a. n.a.	n.a. n.a. n.a.	**/32 **/49 **/57	n.a. n.a. n.a.	29.3 44.8 51.7

Legend: 'var' means dependent on specific product characteristics; 'Test #' means test condition; 'A' average climate; 'W' warmer climate; 'C' colder climate; 'n.a.' means non applicable

*: For variable flow units, the manufacturer may apply a higher leaving water temperature as long as the mean temperature of the test condition is maintained. The mean temperature is calculated as the mean logarithmic temperature difference between the indoor air temperature of 20 °C and the leaving and returning water temperatures when using variable temperature, fixed outlet, and variable flow. If the return temperature is lower than 20°C, the mean temperature is the sum of 20 °C and the part-load ratio of the specific test point multiplied by the logarithmic temperature difference at T_{designh} of the specific climate.

**: With the flow rate as determined in the standard rating conditions at 30/35 for LT applications (respectively at 47/55 for MT applications and 55/65 for HT applications) for units with a fixed flow rate, and with a fixed water-temperature difference of 5 K (respectively of 8 K and 10 K) for units with a variable flow rate. For variable water flow, if the flow obtained from the 5 K (respectively 8 K and 10 K) temperature difference between the outlet and return temperature is lower than the minimum flow indicated by the manufacturer, than this latter value should be used. If cycling occurs, the feed temperature changes (increases) to the adjusted outlet temperature for cycling '(T_{cyc}(T_j))'. T_{cyc}(T_j) is such that the average leaving temperature over the on and off periods equals the outlet temperature for units operating continuously at the same part-load condition. Alternatively, the average of the on and off periods is equal to the mean temperature for units operating continuously at the same part-load condition.

*** = calculated from interpolation of supply/return temperatures (respectively of the mean temperature) at test conditions higher and lower than and closest to T_{biv} or TOL where relevant.

****: Notes on conditions E and F: If TOL > T_{designh}, T_{designh} can only be reached with an electric backup heater elbu. If TOL < T_{designh} then TOL is considered equal to T_{designh} and this test condition and E (TOL) are identical.

***** For other heat sources, the conditions for the outdoor heat exchanger are as follows:

- Ground heat exchanger: inlet 5 °C/outlet: dependent on operating conditions
- Exhaust air: inlet air dry (wet) bulb 20 (15) °C/outlet: dependent on operating conditions
- Ground direct exchange: bath temperature 4 °C.

For ground heat exchangers, the flow rate is set to the value determined in the standard rating conditions for units with a fixed flow rate or with a fixed water temperature difference of 3 K

for units with a variable flow rate. For variable water flow, if the flow obtained from the 3 K temperature difference between the return and outlet temperatures is lower than the minimum flow indicated by the manufacturer, than this latter value should be used.

Table 4

European reference heating season under average, colder, and warmer climate conditions for heat-pump heaters and hybrid heat-pump heaters

Climate conditions	bin_j	1 to 8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
	T_j [°C]	-30 to -23	-	-	-	-	-	-	-	-	-	-	-	-	-	-9	-8	-7	-6	-5	-4	-3
Average	H_j [h/a]														1	25	23	24	27	68	91	89
Colder	H_j [h/a]		1	6	13	17	19	26	39	41	35	52	37	41	43	54	90	125	169	195	278	306
Warmer	H_j [h/a]																					

Climate conditions	bin_j	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	Total hours (H):
	T_j [°C]	-2	-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	
Average	H_j [h/a]	165	173	240	280	320	357	356	303	330	326	348	335	315	215	169	151	105	74	4 910
Colder	H_j [h/a]	454	385	490	533	380	228	261	279	229	269	233	230	243	191	146	150	97	61	6 446
Warmer	H_j [h/a]					3	22	63	63	175	162	259	360	428	430	503	444	384	294	3 590

4. CONTROL, AUXILIARY ENERGY AND STANDBY HEAT-LOSS CORRECTION FACTORS

4.1. Control correction factor F(1)

1. The control correction factor F(1) is shall apply to all heaters.
1. The value of the control correction factor F(1) is equal to 3 percentage points.

4.2. Auxiliary electricity correction factor F(2)

The value of the auxiliary electricity correction factor $F(2)$ shall be expressed in percentage points and shall be calculated in the following way:

- (a) for fuel boiler heaters :

$$F(2) = CC \times \frac{(0.15 \times el_{max} + 0.85 \times el_{min} + 1.3 \times PSB)}{(0.15 \times P4 + 0.85 \times P1)}$$

where:

- CC is the conversion coefficient;

- el_{max} is the full load auxiliary power, meaning electric power consumption, as part of the electric auxiliary energy, at full load P4 of a fuel boiler heater, expressed in kW;
- el_{min} is the part-load auxiliary power, meaning the electric power consumption, as part of the electric auxiliary energy, at part-load P1 of a fuel boiler heater, expressed in kW;
- P_{SB} is the standby-mode power consumption, meaning the electric power consumption of a heater in standby mode, including network standby, expressed in kW;
- $P4$ is the standard-rated heat output expressed in kW;
- $P1$ is the part-load output expressed in kW.

(b) for electric boiler heaters:

$$F(2) = \frac{1.3 \times P_{SB}}{P_4 \times CC}$$

where:

- P_{SB} is the standby-mode power consumption, meaning the electric power consumption of a heater in standby mode, including network standby, expressed in kW;
- $P4$ is the standard-rated heat output expressed in kW;
- CC is the conversion coefficient.

(c) for cogeneration space-heaters and cogeneration heater with backup boiler :

$$F(2) = \frac{CC \times el_{max}}{P_4}$$

where:

- el_{max} is the full-load auxiliary power, meaning electric power consumption, as part of the electric auxiliary energy, at full load P4 of a fuel boiler heater, expressed in kW;
- $P4$ is the standard-rated heat output expressed in kW;
- CC is the conversion coefficient.

(d) for ground heat exchanger heat-pump heaters and hybrid heat-pump heaters comprising ground heat exchanger heat-pump heat generator:

$$F(2) = 5$$

4.3. Standby heat loss correction factor F(3)

The standby heat-loss correction $F(3)$ shall be expressed in percentage points and shall be calculated in the following way:

(a) for boiler heaters:

$$F(3) = \frac{0.5 \times P_{h,l}}{P_4}$$

where:

- $P_{h,l}$ is the heat loss of a boiler heater in operating modes without heat demand, expressed in kW;

– P_4 is the standard-rated heat output expressed in kW.

(b) for other heaters

$$F(3) = 0$$

5. WATER-HEATING ENERGY EFFICIENCY FOR COMBINATION HEATERS

5.1. Water heating test conditions

1. The water-heating tests are performed in the 'out of the box mode'. The only alteration allowed is to enable the measurement of the adaptive-control factor.
2. The declared load profile of a combination heater and the ability of a combination heater to supply water at 50 °C for all declared profiles and climates shall be verified by tests, before proceeding with the remaining water heating measurements.
3. The water-heating measurements shall be carried out for the load profile with the largest reference energy (Q_{ref}) that can be supplied by the combination heater, as set out in Table 7.
4. For measurements under point 4, the cold sanitary water inlet temperature is +10 °C and the ambient temperature is +20 °C if the combination heater is designated for use in a heated space. If the combination heater is designated for use in an unheated space, then it shall be tested at the ambient temperature outdoors or, for heat-pump combination heaters, at the source air temperature.
5. The tests to determine energy efficiency and performance are subject to the following conditions:
 - (i) measurements shall be carried out using the load profiles set out in Table 7;
 - (ii) measurements shall be carried out using a 24-hour measurement cycle as follows:
 - (iii) 00:00 to 06:59: no water draw-off;
 - (iv) from 07:00: water draw-offs according to the declared load profile;
 - (v) from end of last water draw-off until 24:00: no water draw-off.
6. During the test for determining water heating efficiency no space heating may occur. If the heater is equipped with a PFHRD for the recovery of heat resulting from a space-heating operation, the parameter Q_{fuel} for the calculation of water heating efficiency shall be corrected to reflect possible savings, considering the conversion from heat recovered to final energy saved and the relative weight of the heating season in annual operation.
7. When testing with a passive flue heat recovery device (PFHRD), from 06:00 to 21:30 of the profile reference time and when the boiler heater is not performing its water-heating function, the boiler heater shall continuously operate in heating mode with a feed temperature of 43 °C and a return temperature of 37 °C. The daily fuel energy consumption for water heating shall be calculated, by taking proportionally into account fuel consumption in summer mode (166 of 366 days, test without intermediate space heating) and winter mode (200 of 366 days, test with intermediate space heating).

8. Heat-pump combination heaters shall be tested under the conditions set out in Table 5.
9. Heat-pump combination heaters which use ventilation exhaust air as the heat source shall be tested under the conditions set out in Table 6, whereby an alternate source is to be used and declared, if and in as much as the ventilation exhaust air is not enough to perform the requirements of the declared load profile.
10. Combination heaters classified as off-peak combination heaters shall be energised for a maximum period of 8 consecutive hours between 22:00 and 07:00 of the 24-hour tapping pattern. At the end of the 24-hour tapping pattern the combination heaters are energised until the end of the step.
11. For calculating the adaptive-control factor FAC, measurements of the weekly electricity and/or fuel consumption with or without adaptive controls shall be carried out using a two-week measurement cycle as follows:
 - (i) days 1 to 5: random sequence of load profiles chosen from the declared load profile and the load profile one below the declared load profile, self-learning function enabled, and adaptive control disabled;
 - (ii) days 6 and 7: no water draw-offs, self-learning function enabled, and adaptive control disabled;
 - (iii) days 8 to 12: repetition of the same sequence applied for days 1 to 5, and adaptive control enabled;
 - (iv) days 13 and 14: no water draw-offs, and adaptive control enabled;
12. The difference between the useful energy content measured during days 1 to 7 and the useful energy content measured during days 8 to 14 shall not exceed 2 % of Q_{ref} of the declared load profile;
13. Standing losses of hot water storage tanks shall be measured at an ambient temperature of 20 °C and a storage temperature of 65 °C to be achieved and maintained during the test.
14. For tests and test conditions not mentioned here, the transitional methods mentioned in Annex IV apply, as appropriate.

Table 5

Heating standard rating conditions for heat-pump combination water heating: dry bulb air temperatures (wet-bulb temperatures in brackets) and liquid temperatures*

Heat source	Outdoor air	Outdoor air	Outdoor air	Exhaust air	Ground heat exchanger	Ground direct exchange, bath temperature
Climate conditions	Average climate	Colder climate	Warmer climate	All climates		
Temperature (dry bulb / wet bulb)	+7 °C/+6 °C	+2 °C/+1 °C	+14 °C/+12 °C	+20 °C (+15 °C)	+5 °C (inlet)/ +2 °C (outlet)	+ 4 °C

Table 6

Maximum ventilation exhaust air flow rate available for water heating [$q_{v,max w}$] at various loads in m³/h, at 20(15)°C dry(wet) bulb

Declared load profile	S	M	L	XL	XXL	3XL	4XL
Ventilation exhaust air flow rate available for water heating $q_{v,max w}$ in m ³ /h	80	160	190	600	900	1700	3500

5.2. Water-heating energy efficiency (η_{wh}) calculation method

- (a) The water heating energy efficiency η_{wh} , expressed in %, of a combination heater shall be calculated as the ratio between the reference energy Q_{ref} of the declared load profile and the energy required for its generation based on GCV and including primary energy for electricity, calculated as:

$$\eta_{wh} = \frac{Q_{ref}}{(Q_{fuel} + CC \cdot Q_{elec}) \cdot (1 - F_{AC}) + Q_{cor}} \cdot 100$$

where:

- Q_{ref} is the total energy delivered by the load profile used, value from Table 7, in kWh;
- Q_{elec} is the consumption of electricity for water heating over 24 consecutive hours under the declared load profile, expressed in kWh, in terms of final energy, including the electricity use of auxiliary components that are necessary for testing the load profile but not delivered with the product (except the water circulator(s));
- Q_{fuel} is the daily fuel consumption for domestic hot water over 24 consecutive hours under the declared load profile, expressed in kWh, in terms of GCV;
- F_{AC} is the adaptive control factor, as set out in point (b);
- Q_{cor} is the ambient correction term, as set out in point (c).

- (b) The adaptive-control factor:

- (i) for combination heaters without adaptive control is equal to 0;
- (ii) for combination heaters with adaptive control is calculated in the following way:

$$F_{AC} = 1 - \frac{Q_{fuel,week,adaptive} + CC \times Q_{elec,week,adaptive}}{Q_{fuel,week} + CC \times Q_{elec,week}}$$

- (iii) If the result of the calculation is ≥ 0.07 the difference between the useful energy content measured during days 1 to 7 and the useful energy content measured during days 8 to 14 does not exceed 2% of Q_{ref} of the declared load profile the value of F_{AC} is rounded up to 1, and in other cases, the value of F_{AC} is rounded down to 0;

Measurements $Q_{fuel,week,adaptive}$, $Q_{elec,week,adaptive}$, $Q_{fuel,week}$ and $Q_{elec,week}$ shall be carried out in accordance with Section 6.1 point (h).

- (c) Q_{cor} :

- (i) for water heaters with load profiles XL to 4XL is equal to 0;

(ii) for water heaters with load profiles S to L is calculated in the following way:

(1) for heat-pump water heaters:

$$Q_{cor} = -0.23 \times 24h \times P_{stby}$$

(2) for water heaters other than heat-pumps, using fuel combustion for heating sanitary water:

$$Q_{cor} = -0,23 \cdot (Q_{fuel} \cdot (1 - F_{AC}) - Q_{ref})$$

(3) for water heaters other than heat-pumps, using the electric Joule effect for heating sanitary water:

$$Q_{cor} = -0,23 \cdot (CC \cdot Q_{elec} \cdot (1 - F_{AC}) - Q_{ref})$$

Table 7

Water-heating tapping (load) profiles 3XS, XXS, XS, S, M, L, XL, XXL, 3XL, 4XL

h	3XS			XXS			XS			S				M			
	Q_{tap}	f	T_m	Q_{tap}	f	T_m	Q_{tap}	f	T_m	Q_{tap}	f	T_m	T_p	Q_{tap}	f	T_m	T_p
	kWh	l/min	°C	kWh	l/min	°C	kWh	l/min	°C	kWh	l/min	°C	°C	kWh	l/min	°C	°C
07:00	0.015	2	25	0..105	2	25				0.105	3	25		0.105	3	25	
07:05	0.015	2	25											1.4	6	40	
07:15	0.015	2	25														
07:26	0.015	2	25														
07:30	0.015	2	25	0..105	2	25	0.525	3	35	0.105	3	25		0.105	3	25	
08:01														0.105	3	25	
08:15														0.105	3	25	
08:30				0..105	2	25				0.105	3	25		0.105	3	25	
08:45														0.105	3	25	
09:00	0.015	2	25											0.105	3	25	
09:30	0.015	2	25	0..105	2	25				0.105	3	25		0.105	3	25	
10:30														0.105	3	10	40
11:30	0.015	2	25	0..105	2	25				0.105	3	25		0.105	3	10	40
11:45	0.015	2	25	0..105	2	25				0.105	3	25		0.105	3	25	

12:00	0.015 2 25	0..105 2 25			
12:30	0.015 2 25	0..105 2 25			
12:45	0.015 2 25	0..105 2 25	0.525 3 35	0.315 4 10 50	0.315 4 10 50
14:30	0.015 2 25				0.105 3 25
15:00	0.015 2 25				
15:30	0.015 2 25				0.105 3 25
16:00	0.015 2 25				
16:30					0.105 3 25
18:00		0..105 2 25		0.105 3 25	0.105 3 25
18:15		0..105 2 25		0.105 3 40	0.105 3 40
18:30	0.015 2 25	0..105 2 25			0.105 3 40
19:00	0.015 2 25	0..105 2 25			0.105 3 25
19:30	0.015 2 25	0..105 2 25			
20:00		0..105 2 25			
20:30			1.05 3 35	0.42 4 10 50	0.735 4 10 50
20:45		0..105 2 25			
21:00		0..105 2 25			
21:15	0.015 2 25	0..105 2 25			0.105 3 25
21:30	0.015 2 25			0.525 5 40	1.4 6 40
21:35	0.015 2 25	0..105 2 25			
21:45	0.015 2 25	0..105 2 25			
Q_{ref}	0.345	2..100	2.100	2.100	5.845

h	L				XL				XXL				h	3XL			
	Q_{tap}	f	T_m	T_p	Q_{tap}	f	T_m	Q_{tap}	f	T_m	f	T_m		Q_{tap}	f	T_m	T_p
	kWh	l/ min	°C	°C	kWh	l/ min	°C	°C	kWh	l/ min	°C	°C		kWh	l/ min	°C	°C
07:00	0.105	3	25		0.105	3	25		0.105	3	25		07:00	11.2	48	40	
07:05	1.4	6	40										08:01	5.04	24	25	
07:15					1.82	6	40		1.82	6	40		09:00	1.68	24	25	
07:26					0.105	3	25		0.105	3	25		10:30	0.84	24	10	40
07:30	0.105	3	25										11:45	1.68	24	25	
07:45	0.105	3	25		4.42	10	10	40	6.24	16	10	40	12:45	2.52	32	10	50
08:01					0.105	3	25		0.105	3	25		15:30	2.52	24	25	
08:05	3.605	10	10	40									18:30	3.36	24	25	
08:15					0.105	3	25		0.105	3	25		20:30	5.88	32	10	50
08:25	0.105	3	25										21:30	12.04	48	40	
08:30	0.105	3	25		0.105	3	25		0.105	3	25		Q_{ref}	46,76			
08:45	0.105	3	25		0.105	3	25		0.105	3	25		h	4XL			
09:00	0.105	3	25		0.105	3	25		0.105	3	25			Q_{tap}	f	T_m	T_p
09:30	0.105	3	25		0.105	3	25		0.105	3	25			kWh	l/ min	°C	°C
10:00					0.105	3	25		0.105	3	25						
10:30	0.105	3	10	40	0.105	3	10	40	0.105	3	10	40					
11:00					0.105	3	25		0.105	3	25		07:00	22.4	96	40	

11:30	0.105	3	25		0.105	3	25		0.105	3	25		08:01	10.08	48	25	
11:45	0.105	3	25		0.105	3	25		0.105	3	25		09:00	3.36	48	25	
12:45	0.315	4	10	50	0.735	4	10	50	0.735	4	10	50	10:30	1.68	48	10	40
14:30	0.105	3	25		0.105	3	25		0.105	3	25		11:45	3.36	48	25	
15:00					0.105	3	25		0.105	3	25		12:45	5.04	64	10	50
15:30	0.105	3	25		0.105	3	25		0.105	3	25		15:30	5.04	48	25	
16:00					0.105	3	25		0.105	3	25		18:30	6.72	48	25	
16:30	0.105	3	25		0.105	3	25		0.105	3	25		20:30	11.76	64	10	50
17:00					0.105	3	25		0.105	3	25		21:30	24.08	96	40	
18:00	0.105	3	25		0.105	3	25		0.105	3	25		Q_{ref}	93.52			
18:15	0.105	3	40		0.105	3	40		0.105	3	40		<u>Legend:</u> Q_{tap} : energy content f : flow rate T_m : minimum temperature T_p : draw-off temperature				
18:30	0.105	3	40		0.105	3	40		0.105	3	40						
19:00	0.105	3	25		0.105	3	25		0.105	3	25						
20:30	0.735	4	10	50	0.735	4	10	50	0.735	4	10	50					
20:46					4.42	10	10	40	6.24	16	10	40					
21:00	3.605	10	10	40													
21:15					0.105	3	25		0.105	3	25						
21:30	0.105	3	25		4.42	10	10	40	6.24	16	10	40					
Q_{ref}	11.655				19.07				24.53								

6. SEASONAL SPACE-COOLING ENERGY EFFICIENCY

6.1. Seasonal space-cooling energy efficiency of electric reversible heat-pump heaters and hybrid heat-pump heaters with electric heat-pump heat generators

- (a) The seasonal space cooling energy efficiency $\eta_{s,c}$ shall be calculated in the following way:

$$\eta_{s,c} = \frac{1}{CC} \times SEER \times (1 - \sum F(i))$$

where:

- SEER is the seasonal energy-efficiency ratio, calculated in accordance with point (b);
- CC is the conversion coefficient;
- $\sum F(i)$ is the sum of the values of F(1) and F(2), where:
 - F(1) is the control correction factor, calculated in accordance with Section 5.1.;
 - F(2) is the auxiliary electricity correction factor, calculated in accordance with Section 5.2. point (d).

- (b) The seasonal energy-efficiency ratio SEER shall be calculated in the following way:

$$SEER = \frac{Q_C}{Q_{CE}}$$

where:

- Q_C is the reference annual cooling demand, calculated in accordance with point (c);
- Q_{CE} is the reference annual energy consumption for cooling, calculated in accordance with point (d).

- (c) The reference annual cooling demand Q_C shall be calculated as follows:

$$Q_C = P_{\text{design},c} \times H_{CE}$$

where:

- $P_{\text{design},c}$ is the design cooling load;
- H_{CE} is the equivalent active mode hours for cooling, as set out in Table 2,

- (d) The reference annual energy consumption for cooling Q_{CE} shall be calculated as follows:

$$Q_{CE} = \frac{Q_C}{SEER_{on}} + H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}$$

where:

- Q_C is the reference annual cooling demand;
- $SEER_{on}$ is the active mode energy-efficiency ratio, calculated in accordance with point (e);
- H_{TO} are the annual hours in thermostat off mode, indicated in Table 2;

- H_{SB} are the annual hours in standby mode, indicated in Table 2;
- H_{CK} are the annual hours in crankcase mode, indicated in Table 2;
- H_{OFF} are the annual hours in off mode, indicated in Table 2;
- P_{TO} is the measured power in thermostat off mode;
- P_{SB} is the measured power in standby mode;
- P_{CK} is the measured power in crankcase mode;
- P_{OFF} is the measured power in off mode.

(e) The active mode seasonal energy-efficiency ratio $SEER_{on}$ shall be calculated as follows:

$$SEER_{on} = \frac{\sum_{j=1}^n h_j \times P_c(T_j)}{\sum_{j=1}^n h_j \left(\frac{P_c(T_j)}{EER_{bin}(T_j)} \right)}$$

where:

- h_j is the frequency of occurrence of the outdoor temperature in temperature bin j , in hours;
- $P_c(T_j)$ is the part load for cooling;
- $EER_{bin}(T_j)$ is the bin-specific energy-efficiency ratio, calculated in accordance with point (g).

(f) The part load for cooling $P_c(T_j)$ shall be calculated as follows:

$$P_c(T_j) = P_{design,c} \times plc(T_j)$$

where:

- $P_{design,c}$ is the design cooling load;
- $plc(T_j)$ is the part-load ratio.

(g) Declared values for $EER_d(T_j)$ and $P_{dc}(T_j)$ are the measured values at the part-load test conditions for outdoor temperatures T_j ('bins') A to D and $P_{design,c}$, as indicated in Table 9 and Table 10. The values for $EER_{bin}(T_j)$ shall be determined through interpolation and extrapolation of known values. If the space-heater cooling capacity in a bin is too high for the cooling demand in the bin by more than 10 %, the space-heater will cycle on/off and a degradation factor (C_{dc}) and a capacity ratio (CR) has to be used to calculate the EER_{bin} for T_j in the following way:

$$EER_{bin} = \frac{EER_d \times CR}{C_{dc} \times CR + (1 - C_{dc})}$$

where:

- EER_d is the declared energy-efficiency ratio, for the conditions of Table 9 and Table 10;
- CR is the capacity ratio, calculated in accordance with point (h);

- C_{dc} is the degradation coefficient for cycling behaviour; it is either 0.9 by default or it can be determined by a series of cyclic tests; it is then calculated as the ratio between the power during the on phase and the power during the off phase divided by the power during the on phase.

For cycling, the water-temperature regime in the on phase is modified to maintain the same time-average water-temperature regime over the whole on/off cycle as in the stationary condition without cycling.

- (h) The capacity ratio CR for the purposes of point (g) is calculated in the following way:

$$CR = plc(T_j) \times \frac{P_{designc}}{P_{dc}}$$

where:

- $plc(T_j)$ is the cooling part-load ratio;
- $P_{designc}$ is the design cooling load;
- P_{dc} is the minimum capacity for cooling in continuous operation.

6.2. Seasonal space-cooling energy efficiency of reversible fuel heat-pump heaters and hybrid heat-pump heaters with fuel heat-pump heat generators,

- (a) The seasonal space-cooling energy efficiency $\eta_{s,c}$ shall be calculated in the following way:

$$\eta_{s,c} = SPERC \times (1 - \sum F(i))$$

where:

- $SPERC$ is the seasonal primary energy ratio in cooling mode, calculated in accordance with point (b);
- $\sum F(i)$ is the sum of the values of $F(1)$ and $F(2)$, where:
 - $F(1)$ is the control correction factor, calculated in accordance with Section 5.1.;
 - $F(2)$ is the auxiliary electricity correction factor, calculated in accordance with Section 5.2. point (d).

- (b) The seasonal primary energy ratio in cooling mode $SPERC$ shall be calculated as follows:

$$SPERC = \frac{1}{\frac{1}{SFUEc} + \frac{CC}{SAEFc}}$$

where:

- $SFUEc$ is the seasonal fuel-utilization efficiency in cooling mode, calculated in accordance with point (c);
- $SAEFc$ is the seasonal auxiliary energy factor in cooling mode, calculated in accordance with point (d);
- CC is the conversion coefficient.

- (c) The seasonal fuel-utilization efficiency in cooling mode $SFUEc$ shall be calculated as follows:

$$SFUE_c = \frac{\sum_{j=1}^n h_j \times P_c(T_j)}{\sum_{j=1}^n h_j \times \frac{P_c(T_j)}{FUE_c(T_j)}}$$

where:

- h_j is the frequency of occurrence of the outdoor temperature in temperature bin j , in hours;
- $P_c(T_j)$ is the part-load for cooling;
- $FUE_c(T_j)$ is the bin-specific fuel-utilization efficiency for cooling at partial load.

- (d) The seasonal auxiliary energy factor in cooling mode (SAEF_c) shall be calculated in the following way:

$$SAEF_c = \frac{Q_c}{Q_{CE}}$$

where:

- Q_c is the reference annual cooling demand, calculated in accordance with point (e);
- Q_{CE} is the annual energy consumption for cooling, calculated in accordance with point (f).

- (e) The reference annual cooling demand (Q_c) shall be calculated in the following way:

$$Q_c = P_{design,c} \times H_{CE}$$

where:

- $P_{design,c}$ is the design cooling load;
- H_{CE} are the equivalent active mode hours for cooling as set out in Table 2;

- (f) The annual energy consumption for cooling (Q_{CE}) shall be calculated in the following way:

$$Q_{CE} = \frac{Q_c}{SAEF_{c,on}} + H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{OFF} \times P_{OFF} + H_{CK} \times P_{CK}$$

where:

- Q_c is the reference annual cooling demand,
- $SAEF_{c,on}$ is the seasonal auxiliary energy factor in cooling mode in active mode, calculated in accordance with point (g);
- H_{TO} are the annual hours in thermostat-off mode, indicated in Table 2;
- H_{SB} are the annual hours in standby mode, indicated in Table 2;
- H_{CK} are the annual hours in crankcase mode, indicated in Table 2;
- H_{OFF} are the annual hours in off mode, indicated in Table 2;
- P_{TO} is the measured power in thermostat-off mode;
- P_{SB} is the measured power in standby mode;
- P_{CK} is the measured power in crankcase mode;

- P_{OFF} is the measured power in off mode.
- (g) The seasonal auxiliary energy factor in cooling mode in active mode shall be calculated in the following way:

$$SAEF_{c,on} = \frac{\sum_{j=1}^n h_j \times P_c(T_j)}{\sum_{j=1}^n h_j \times \frac{P_c(T_j)}{AEF_c(T_j)}}$$

where:

- h_j is the frequency of occurrence of the outdoor temperature in temperature bin j , in hours;
 - $P_c(T_j)$ is the part load for cooling;
 - $AEF_c(T_j)$ is the auxiliary energy factor in cooling mode at partial load.
- (h) The conditions for calculating the $SGUE_c$ and the $SAEF_{c,on}$ shall consider:
- (1) the reference design conditions set out in Table 11;
 - (2) the European average cooling season set out in Table 11;
 - (3) if applicable, the effects of the degradation of energy efficiency caused by cycling depending on the type of control of the cooling capacity.

Table 8
Standard rating conditions for cooling

		Outdoor-side heat exchanger		Indoor-side heat exchanger	
		inlet temperature °C	outlet temperature °C	inlet temperature °C	outlet temperature °C
Cooling mode	Air-to-water (low cooling temperature applications)	35	N/A	12	7
	Air-to-water (for medium cooling temperature applications)	35	N/A	23	18
	Exhaust air-to-water (for low cooling temperature applications)	27	N/A	12	7
	Exhaust air-to-water (for medium cooling temperature applications)	27	N/A	23	18
	Water-to-water (for low cooling temperature applications) from cooling tower	30	35	12	7
	Water-to-water (for	30	35	23	18

	medium cooling temperature applications) from cooling tower				
	Water/brine-to-water (for low cooling temperature applications) from ground heat exchanger	10	15	12	7
	Water/brine-to-water (for medium cooling temperature applications) from ground heat exchanger	10	15	23	18
	DX Bath temperature (for low cooling temperature applications)	30	N/A	12	7
	DX Bath temperature (for medium cooling temperature applications)	30	N/A	23	18

Table 9

Part-load test conditions for cooling: air-to-water units

	Part-load ratio	Part-load ratio	Outdoor heat exchanger		Indoor heat exchanger		
			Outdoor air dry bulb temperature	Exhaust air dry bulb temperature	Low-temperature application Inlet/outlet water(brine) temperatures		Medium-temperature application Inlet/outlet water(brine) temperatures
					Fixed outlet	Variable outlet ^b	
		%	°C	°C	°C	°C	°C
A	$(35-16)/(T_{\text{designc}} - 16)$	100.00	35	27	12 / 7	12 / 7	23 / 18
B	$(30-16)/(T_{\text{designc}} - 16)$	73.68	30	27	^a / 7	^a / 8.5	^a / 18
C	$(25-16)/(T_{\text{designc}} - 16)$	47.37	25	27	^a / 7	^a / 10	^a / 18

D	$(20-16)/(T_{\text{designc}} - 16)$	21.05	20	27	^a / 7	^a / 11.5	^a / 18
^a With the flow rate as determined during ‘A’ test for units with a fixed flow rate or with a fixed water temperature difference of 5 K for units with a variable flow rate. If, for any of the test conditions the resulting flow rate is below the minimum flow rate, then this minimum flow rate is used as a fixed flow rate with the outlet temperature for this test condition. ^b If the variable outlet temperature is above the maximum of the operating range of the unit, this maximum is used.							

Table 10

Part-load test conditions for cooling: ground / cooling tower-to-water units

Part-load ratio	Part-load ratio	Outdoor heat exchanger			Indoor heat exchanger		
		Cooling tower or water (brine) loop	Ground coupled application	DX	Low-temperature heating application		Medium-temperature heating application
		Inlet/outlet water (brine) temperatures	Inlet/outlet water (brine) temperatures	Bath temperature	Inlet/outlet water (brine) temperatures		Inlet/outlet water (brine) temperatures
					Fixed outlet	Variable outlet ^c	
	%	°C	°C	°C	°C	°C	°C
(35–16)/ (<i>T</i> _{designc} – 16)	100	30 / 35	10 / 15	30	12 / 7	12 / 7	23 / 18
(30–16)/ (<i>T</i> _{designc} – 16)		73.68	26 / ^b	10 / ^b	30	^a / 7	^a / 8.5
(25–16)/ (<i>T</i> _{designc} – 16)	47.37	22 / ^b	10 / ^b	30	^a / 7	^a / 10	^a / 18
(20–16)/ (<i>T</i> _{designc} – 16)		21.05	18 / ^b	10 / ^b	30	^a / 7	^a / 11.5
^a With the flow rate as determined during ‘A’ test for units with a fixed flow rate or with a fixed water temperature difference of 5 K for units with a variable flow rate. If, for any of the test conditions the resulting flow rate is below the minimum flow rate, then this minimum flow rate is used as a fixed flow rate with the outlet temperature for this test condition.							

^b With the flow rate as determined during ‘A’ test for units with a fixed flow rate or with a fixed water temperature difference of 5 K for units with a variable flow rate. If, for any of the test conditions the resulting flow rate is below the minimum flow rate, then this minimum flow rate is used as a fixed flow rate with the inlet temperature for this test condition.

^c If the variable outlet temperature is above the maximum of the operating range of the unit, this maximum is used.

Table 11
European cooling season

Bins	Outdoor temperature (dry bulb)	‘Average cooling season’
		bin hours
j	T _j	h _j
#	°C	h/annum
1	17	205
2	18	227
3	19	225
4	20	225
5	21	216
6	22	215
7	23	218
8	24	197
9	25	178
10	26	158
11	27	137
12	28	109
13	29	88
14	30	63
15	31	39
16	32	31
17	33	24
18	34	17
19	35	13
20	36	9
21	37	4
22	38	3
23	39	1
24	40	0

7. SOUND POWER

7.1. Heat-pump heaters and hybrid heat pump heaters in heating mode

The sound-power level of heat-pump heaters shall be assessed using the same settings for parameters that affect the sound-power level, such as compressor speed and stages, fan speed, etc., as used for determining the heat output for space-heating at part-load conditions C (settings 1) or B (settings 2) for average climate and medium-temperature heating applications in heating mode (or low-temperature application for low-temperature heat pump heater), as specified in Table 13.

Table 13**Heating mode sound-power test conditions for heat-pump heaters and hybrid heat-pump heaters**

Heat-pump source	heat exchanger – inlet dry (wet) bulb temperature in °C	Settings that affect sound power, such as compressor and fan speed or stage ***	
		Settings 1	Settings 2
air-to-water	7 (6) **	Part-load condition C	Part-load condition B
exhaust air-to-water	20 (15)	Part-load condition C	Part-load condition B
Ground heat exchanger	5 /*	Part-load condition C	Part-load condition B
Ground exchange	4	Part-load condition C	Part-load condition B

* With the fixed or variable water flowrate of Table 10, calculated in agreement with standard rating conditions of Table 3.

** A lower temperature down to 2 °C can be chosen if the unit can stabilise operations without defrost in the chosen conditions.

*** In case the energy efficiency at part-load condition results from the interpolation amongst different capacity stages, the sound power should be measured based on the higher of the two capacity stages.

7.2. Heaters other than heat-pump heaters and hybrid heat-pump heaters and cooling mode

For all heaters that are not heat-pump heaters or hybrid heat-pump heaters, the sound power tests are to be conducted at standard-rated heat output.

For reversible heat-pump heaters or reversible hybrid heat-pump heaters in cooling mode, the sound power tests are to be conducted at standard-rated cooling output.

8. SOLAR DEVICES

8.1. Solar device testing

- (a) The solar collector(s) and, if applicable, the solar hot water storage tank(s) of the solar device, shall be tested separately, except for a solar device, for which the solar collector(s) and hot-water storage tank(s) form an inseparable unit or need to be tested together in order to determine the solar-device efficiency, and which is placed on the market as a single unit.
- (b) The standards as referenced in Annex IV shall be applied.
- (c) The weather data to be used for determining GTY shall relate to the location of:
 - (i) Helsinki or Stockholm for the colder climate;
 - (ii) Strasbourg or Würzburg for the average climate; and
 - (iii) Athens for the warmer climate.

- (d) The orientation for non-tracking collectors shall be south for all locations.
- (e) The inclination for non-tracking collectors shall be:
 - (i) 45° for the colder climate;
 - (ii) 35° for the average climate; and
 - (iii) 25° for the warmer climate.
- (f) For collectors designed to track the path of the sun, the optimal tracking parameters declared by the manufacturer for the locations indicated in point (c) shall be used.
- (g) When performing tests of solar collectors and/or subsequent calculations, the volume of the solar storage tank shall not be less than 0.06 litre of water per kWh of GTY of the collector array.

8.2. Solar device efficiency for water heating

- (a) The solar device efficiency for water heating $\eta_{sol,wh}$ shall be calculated per climate condition and load profile as:

$$\eta_{sol,wh} = f_{sol,wh,lp} \times f_{tank}$$

where:

- f_{tank} is the tank factor, as set out in Table 13, specified for the energy-efficiency class of the storage tank as indicated in the product-information sheet of the storage tank;
- $f_{sol,wh,lp}$ is the solar-device factor, calculated in accordance with point (b).
- (b) The solar device factor $f_{sol,wh,lp}$ shall be calculated per climate condition and load profile in the following way:

$$f_{sol,wh,lp} = \left(a \times \left(\frac{GTY}{Q_{wh,sol}} \right)^2 + (b + d \times f_{profile}) \times \frac{GTY}{Q_{wh,sol}} + c \right)$$

where:

- GTY is the climate-specific gross thermal yield per year (kWh/yr) of the solar device, calculated in accordance with point (c);
- $Q_{wh,sol}$ means the annual solar water heating demand, for the applicable load profile, calculated in accordance with point (d);
- coefficient a , b , c and d are the solar device water heating efficiency coefficients per climate condition, set out in Table 14;
- $f_{profile}$ is tapping load profile specific coefficient as set out in Table 15.

The solar-device efficiency for water heating η_{wh} as calculated for the combinations of GTY and Q_{ref} shall not be less than 100% and not more than the upper limits 240%, 450% and 500% for the colder, average and warmer climate respectively.

Table 13
Tank factor

Storage-tank energy-label class	A	B	C	D
Storage-tank correction factor	1.20	1.15	1.1	1.05

f_{tank}				
------------	--	--	--	--

Table 14

Coefficients for calculation of $\eta_{sol,wh}$

Solar-device water-heating efficiency coefficients per climate	a	b	c	d
Average	-0.22	1.93	0.55	0.36
Colder	-0.52	1.94	0.60	0.28
Warmer	1.17	0.59	0.83	0.50

Table 15

Load profile specific coefficient for calculation of $\eta_{sol,wh}$

Load profile	M	L	XL	XXL	3XL	4XL
$f_{profile} (-)$	0	0.92	1.38	1.64	2.43	3.56

- (c) The GTY of a solar device shall be calculated in the following way:
- (i) if the solar collector(s) of the solar device were tested separately from the hot water storage tank of the solar device, the GTY shall be calculated using the calculation method referred to in Annex IV;
 - (ii) if the solar collector(s) and the hot water storage tank of the solar device were tested together;
 - (iii) the GTY shall be equal to the amount of solar heat delivered (Q_{sol}), determined for the smallest load profile, for which the non-solar heat required (Q_{nonsol}) for the 'warmer' climate conditions is equal to or higher than the minimum values shown in Table 16.

Table 16

The minimum value for Q_{nonsol}

	M	L	XL	XXL	3XL	4XL
Limit value (kWh/a)	520	950	1510	1910	3570	7060

- (d) The non-solar heat required (Q_{nonsol}), expressed in kWh/a, shall be calculated in the following way:

$$Q_{nonsol} = Q_{wh,sol} - Q_{sol}$$

where:

- $Q_{wh,sol}$ is the annual solar water heating demand, calculated in accordance with point (3), and expressed in kWh/a;
- Q_{sol} is the solar heat delivered, determined using standards referred to in Annex IV, and expressed in kWh/a;

- (e) The annual solar-water-heating demand ($Q_{wh,sol}$) shall be calculated in the following way:

$$Q_{wh,sol} = 0.6 * 366 * (Q_{ref} + 1.09)$$

8.3 Solar-device efficiency for space heating

The solar-device efficiency for space heating $\eta_{sol,sh}$ shall be calculated per climate condition and load profile in the following way:

$$\eta_{sol,sh} = f_{sol,sh} \times f_{tank}$$

where:

- $f_{sol,sh}$ is the solar device factor for space heating, calculated in accordance with letter (b),
- f_{tank} is the tank factor, as set out in Table 13, specified for the energy-efficiency class of the storage tank as indicated in the product information sheet of the storage tank based on the Regulation [EL for water heaters and storage tanks].

The solar device factor for space heating shall be calculated in the following way:

$$f_{sol,sh} = a * \left(\frac{GTY}{Q_H}\right)^2 + b * \left(\frac{GTY}{Q_H}\right) + c$$

where:

- GTY is the gross thermal yield per year (kWh/a) of the solar device for climate conditions, calculated in accordance with point (c), Section 7.2.;
- Q_H is the annual space-heating demand (kWh/a), calculated in accordance with point (c);
- a , b , and c are the coefficients set out in Table 17.

The calculated solar device efficiency for the combinations of GTY and Q_H shall be not less than 100 % and not more than 300 %.

Table 17
Coefficients for calculation of $\eta_{sol,sh}$

Climate conditions	Solar-device space-heating efficiency coefficients		
	a	b	c
Average	0.00	0.50	1.00
Colder	0.00	0.61	1.00
Warmer	0.17	0.23	1.00

Q_H shall be calculated in the following way:

- For heat pump and hybrid heat pump heaters: $Q_H = P_{design,h} \times H_{HE}$
- For other heat generators: $Q_H = P_4 \times H_{HE}$
- where H_{HE} value given in Table 2 for the various climates.

9. TEMPERATURE CONTROLS

The contribution factor of temperature controls to the seasonal space-heating energy efficiency of packages ('TC', expressed in percentage points) is set out in Table 18.

Table 18

Contribution factor of temperature controls to η_{sh} for packages (TC)

Control class	TC (percentage points)
I	1
II	2
III	1.5
IV	2
V	2.5
VI	3.5
VII	2.5
VIII	5

Where:

- Control class I – Room Thermostat, on/off: A room thermostat that controls the on/off operation of a heater. Performance parameters, including switching differential and room-temperature-control accuracy are determined by the thermostat's mechanical construction.
- Control class II – Weather compensator control, modulating: A heater flow temperature control that varies the set point of the flow temperature of water leaving the heater dependent upon the prevailing outside temperatures and a selected weather compensation curve. Control is achieved by modulating the output of the heater.
- Control class III – Weather compensator control, on/off: A heater flow temperature control that varies the set point of the flow temperature of water leaving the heater dependent upon the prevailing outside temperature and a selected weather compensation curve. Heater flow temperature is varied by controlling the on/off operation of the heater.
- Control class IV – A generic load-compensating control, proportional on/off, time-proportional-integral (TPI) controls and other similar control devices that use different algorithms, TPI and similar control strategies that reduce mean water temperature, improve room-temperature-control accuracy and improve system efficiency.
- Control class V – Modulating room thermostat, modulating: An electronic room thermostat that varies the flow temperature of the water leaving the heater dependent

upon the deviation of the measured room temperature from room thermostat set point. Control is achieved by modulating the output of the heater.

- Control class VI – Weather compensator and room sensor, modulating: A heater flow temperature control that varies the flow temperature of water leaving the heater dependent upon the prevailing outside temperature and a selected weather compensation curve. A room-temperature sensor monitors room temperature and adjusts the compensation curve parallel displacement to improve room comfort. Control is achieved by modulating the output of the heater.
- Control class VII – Weather compensator and room sensor, on/off: A heater flow temperature control that varies the flow temperature of water leaving the heater dependent upon the prevailing outside temperature and a selected weather compensation curve. A room-temperature sensor monitors room temperature and adjusts the compensation curve parallel displacement to improve room comfort. Heater flow temperature is varied by controlling the on/off operation of the heater.
- Control class VIII – Multi-sensor room temperature control, modulating or proportional on/off: An electronic control, equipped with three or more room sensors that varies the flow temperature of the water leaving the heater dependent upon the deviation of the aggregated measured room temperature from room sensor set points. Control is achieved by modulating or using a proportional on/off strategy to regulate the output of the heater.

10. SEASONAL SPACE-HEATING EFFICIENCY OF PACKAGES

- (a) The seasonal space-heating efficiency of a package $\eta_{s,pack}$ shall be calculated in the following way:

$$\eta_{s,pack} = \eta_{sol,sh} \times \eta_{sh} \times f_{tank} \times (1 - F(1) + TC)$$

where:

- $\eta_{sol,sh}$ is the solar-device space-heating efficiency of the solar device included in the package, in %, indicated in the product-information sheet for this solar device;
 - η_{sh} is the space-heating efficiency of the heater included in the package, indicated in the product information sheet for this heater;
 - $F(1)$ is the control correction, calculated in accordance with Section 5 of this Annex;
 - TC is the temperature control value, as set out in Table 18, Section 10;
 - f_{tank} is the tank factor, as set out in Table 13, Section 10.2, specified for the energy-efficiency class of the storage tank, indicated in the product information sheet of this storage tank based on the Regulation [EL for water heaters and storage tanks].
- (b) If the package for which the seasonal space-heating efficiency is calculated in accordance with point (a) does not include:
- (i) a solar device - $\eta_{sol,sh}$ is equal to 1;
 - (ii) a tank - f_{tank} is equal to 1;
 - (iii) a temperature control of classes I-VIII as described in Section 10 – TC is equal to 1.

11. WATER HEATING EFFICIENCY OF A PACKAGE

The water-heating efficiency of a package is calculated per climate condition and load profile in the following way:

$$\eta_{wh,pack} = \eta_{sol,wh,lp} * \eta_{wh,lp} * f_{SWHRD,lp}$$

where:

- $\eta_{sol,wh,lp}$ is the solar-device efficiency for water heating of the solar device included in the package, in %, indicated in the product information sheet for the solar device included in the package;
- $\eta_{wh,lp}$ is the water-heating energy efficiency of the combination heater included in the package, indicated in the product-information sheet for this combination heater;
- $f_{SWHRD,lp}$ is the shower-water heat-recovery device factor of the shower-water heat-recovery device included in the package, indicated in the product-information sheet for this shower-water heat-recovery device.

12. SHOWER WATER HEAT RECOVERY DEVICE

12.1. Testing of the shower-water heat-recovery device

- (a) The shower water flow rate and the incoming cold water flow rate shall be matched.
- (b) The shower water flow rate shall have a temperature between 35 and 40 °C and the incoming cold water a temperature of 10 °C.
- (c) The combined volume of flow rates for the highest flow rates at which the shower water heat recovery devices supplied in the package have been tested exceeds the load profile flow rate for the water heater package as indicated in Table 7.

12.2. Shower-water heat-recovery device factor

- (a) The shower water heat recovery device factor $f_{SWHRD,lp}$ is calculated, in % as:

$$f_{SWHRD,lp} = \frac{100}{\left(100 - (\eta_{SWHRD,lp} * 0.64)\right)}$$

Where $\eta_{SWHRD,lp}$ is the shower water heat recovery device efficiency for the declared load profile of the combination heater included in the package, calculated as set out in point (b) or (c) accordingly. If the package includes more than one shower-water heat-recovery device, the shower-water heat-recovery device efficiency is calculated in accordance with point (d).

- (b) The shower-water heat-recovery device efficiency for a load profile $\eta_{SWHRD,lp}$, established at one flow rate, is calculated in the following way:
 - (i) If the shower-water heat-recovery device efficiency η_i has been established at a flow rate q_i equal to the load profile flow rate $q_{V,lp}$, the $\eta_{SWHRD,lp}$ for the declared load profile is the η_i .
 - (ii) If the shower-water heat-recovery device efficiency has been established at a flow rate of 12.5 l/min ($\eta_{12.5}$) and the applicable load profile flow rate $q_{V,lp}$ is lower, the $\eta_{SWHRD,lp}$ for the declared load profile is calculated as:

$$\eta_{SWHRD,lp} = \eta_{12.5} + (0.8 * 0.01 * (12.5 - q_{V,lp}))$$

- (c) The shower water heat recovery device efficiency for a load profile $\eta_{SWHRD,lp}$, established at two flow rates, one of which is 12.5 l/min ($\eta_{12.5}$) and the other is lower (η_i), and the applicable load profile flow rate $q_{V,lp}$ is below 12.5 l/min, is calculated in the following way:

$$\eta_{SWHRD,lp} = \eta_{12.5} + \left(0.8 * \frac{\eta_{12.5} - \eta_i}{q_{V,12.5} - q_{V,i}} * (q_{V,lp} - 12.5) \right)$$

where:

- $\eta_{12.5}$ is the shower water heat recovery device efficiency established in a test at a flow rate of 12.5 l/min;
 - η_i is the efficiency of the shower-water heat-recovery device efficiency established in a test at a flow rate other than 12.5 l/min;
 - $q_{12.5}$ is the water flow rate of 12.5 l/min used in the test;
 - $q_{V,i}$ is the water flow rate other than 12.5 l/min used in the test;
 - $q_{V,lp}$ is the applicable load profile flow rate indicated in Table 19.
- (d) The $\eta_{SWHRD,lp}$ for a package including multiple shower water heat recovery devices shall be calculated as the flow rate weighted average of the efficiencies established for the individual shower water heat recovery devices.

Table 19
Flow rate $q_{V,lp}$ per load profile

Load profile	XS	S	M	L	XL	XXL	3XL	4XL
$q_{V,lp}$ (l/min)	3	5	6	8	8	12	48	96

ANNEX IV

Transitional methods

References and qualifying notes for space heaters and combination heaters

(The source of all references is CEN unless otherwise indicated)

Parameter	Reference/ Title	Notes and short description
-----------	------------------	-----------------------------

1. FUEL BOILER HEATERS USING GASEOUS FUELS

η, P, design types, P_{stby} ($P_{h,l}$), Sound power indoor, outdoor	<i>EN 15502-1:2021+A1:2023 Gas-fired heating boilers – Part 1: General requirements and tests;</i>	
Useful nominal heat output P_N ($= P_4$) and useful efficiency η_u ($=\eta_4$) at standard-rated heat output	§ 3.1.6.1 Nominal output (definition); § 3.1.5.7 Useful efficiency (definition, symbol); § 9.2.2 (test);	Useful output P_N at 80 °C/60 °C stated by the manufacturer in kW. Useful efficiency η_u is the ratio of the useful output to the heat input in GCV, expressed as a percentage. At the nominal boiler heat input (or minmax average for range-rated boilers) the water flow rate through the boiler is adjusted to obtain a return water temperature of (60 ± 1) °C and a temperature difference between flow and return water temperature of (20 ± 2) °C.
Design types, definitions	§ 3.1.10. Design types of boilers with definitions of ‘combination-boiler’, ‘low-temperature boiler’ and ‘condensing boiler’.	
Nominal condensing heat output at 30 % P_N ($= P_l$) and useful efficiency η_l at 30 % part-load and 30/50 temperature regime	§ 3.1.6.2. Nominal condensing heat output at 50 °C/30 °C water temperature regime § 9.3.2. Useful efficiency at part-load, Tests; § 9.5.2.1. Conversion from NCV to GCV	tests are carried out at 30 % of nominal heat input, at test return temperatures 30 ± 0.5 °C (condensing boiler), 37 ± 1 °C (low-temperature boiler) or 47 ± 1 °C (standard boiler) or 50 ± 1 °C (other boiler). <i>Feed temperature of 50 °C for condensing boiler heaters is to be applied</i>
Standby heat loss P_{stby} ($P_{h,l}$)	§ 9.3.2.3.1.3 Standby losses (test);	In a circuit with (spent) boiler and pump, an auxiliary electric boiler keeps the water at a temperature

		(30±5) K above ambient. The electricity use of the auxiliary boiler, corrected for inherent losses of the test circuit and thermal contribution of the pump is P_{stby} ($P_{h,l}$).
Seasonal space-heating energy efficiency in active mode η_{son} and overall η_s	§ 9.4.6. η_{son} definition $\eta_{son} = 0.85 \times \eta_1 + 0.15 \times \eta_4$ also defines correction factors F(1), F(2), F(3)	η_s formula needs to be adapted as follows: $\eta_{s,h} = \eta_{son} \times \left(1 - \frac{\sum F(i)}{100\%}\right)$
Emission of nitrogen oxides NO _x	§ 8.13. NO _x (classification, test- and calculation methods)	NO _x emission values are to be expressed in gross calorific value GCV. §8.13.2.1 already distinguishes correction factors to the ecodesign limits for G30 and G31 test gases, which is now part of the Annex II of this regulation .
Remote control	§ 5.7.9 Instructions for safe remote control operations	On data exchange, see clause 7.8 of EN 13611:2019
Sound-power level indoors L _{WA}	<i>EN 15036 - 1:2006 Heating boilers - Test regulations for airborne noise emissions from heat generators</i>	
Sound-power level outdoors L _{WA}	<i>EN 15036 - 2:2006 Heating boilers - Test regulations for airborne noise emissions from heat generators</i>	

2. FUEL BOILER HEATERS USING LIQUID FUELS

General conditions	test	EN 304:2017; Heating boilers - Test code for heating boilers for atomising oil burners; Section 6 ('Tests')	Notes
Useful nominal heat output P_N (= P_4) and useful efficiency η_u (= η_4) at standard-rated heat output	§ 6.2. P_N (= P_4) definition § 6.3. η_u (= η_4) definition annex A.10. Conversion NCV to GCV		as gas-fired boilers
Nominal condensing heat output at 30% P_N (= P_1) and useful efficiency η_1 at 30 % part load and 30/50 temperature regime	§ 6.8. η_1 at 30 % part load § 6.5.4.1. direct method (<i>to be used</i>)		as gas-fired boilers

Standby heat loss P_{stby} ($P_{h,l}$)	§ 6.7.3 Standby heat loss method 2	Method 2 is identical to the test and calculation method for gas boilers.
Seasonal space-heating energy efficiency in active mode η_{son} with test results for useful output P	<p>§ 6.10. η_{son} definition annex A.10</p> $\eta_{son} = 0.85 \times \eta_l + 0.15 \times \eta_4$ <p>also defines correction factors F(1), F(2) and F(3)</p>	<p>η_s formula needs to be adapted as follows:</p> $\eta_{s,h} = \eta_{son} \times \left(1 - \frac{\sum F(i)}{100\%}\right)$ <p>(F(4) coefficient to be removed in standard)</p> <p>For B1 boiler testing see also</p> <p>EN 303-1:2017. Part 1: Heating boilers with forced draught burners --Terminology</p> <p>EN 303-2:2017. Part 2: Special requirements atomizing burners</p> <p>EN 303-4:2017. Part 4: Special requirements forced draught burners up to 70 kW</p>
Emission of nitrogen oxides NO _x	<p>EN 267:2020</p> <p><i>Automatic forced draught burners for liquid fuels;</i></p> <p>§ 5. Testing. ANNEX B. Emission measurements and corrections.</p> <p>EN 304:2017</p> <p>Weighting of emissions at standard-rated conditions and at 30 % load ^6.17.2</p>	
Sound-power level indoors L _{WA}	EN 15036 - 1:2006 Heating boilers - Test regulations for airborne noise emissions from heat generators	
Sound-power level outdoors L _{WA}	EN 15036 - 2:2006 Heating boilers - Test regulations for airborne noise emissions from heat generators	

3. ELECTRIC BOILER SPACE-HEATERS AND ELECTRIC BOILER COMBINATION HEATERS

Seasonal space-heating energy efficiency η_s of electric boiler space-	European Commission: See Annex III	
---	---------------------------------------	--

heaters and electric boiler combination heaters		
---	--	--

4. COGENERATION SPACE-HEATERS AND COGENERATION HEATER WITH BACKUP BOILER

General test conditions	EN 50465:2015/A1:2019. Gas appliances – Combined heat and power appliance of nominal heat input inferior or equal to 70 kW	Notes
Nominal heat output $P_N (= P_4)$ and useful efficiency $\eta_u (= \eta_4)$ at standard-rated heat output	§ 3.7.4.3 Nominal heat output (in kW) § 6.6.1 Efficiency (definitions) § 7.6.1 Efficiency (test)	$P_N (= P_4)$ corresponds to $P_{th n}$; Different from § 7.6.1 the standard-rated heat output test is always to be done at 80/60 °C and always at declared (maximum) heat output. Efficiency is always with heat input in GCV.
Nominal electric power output P_{el}	§ 3.7.4.5. net AC electric power output (in kW)	
Overall efficiency	§ 3.7.5 ratio of the useful heat output and the net AC electric power output to the heat input (in %)	Note that in the Regulation the electric power output is multiplied by a factor 2.65 to indicate the energy savings. Useful heat output has the same meaning of the heat output mentioned in the Regulation.
Standby heat loss P_{stby} ($P_{h,l}$) and auxiliary electricity	§ 7.6.2, § 6.6.4, § 6.6.3	
Emission of nitrogen oxides NO_x	§7.8.2 NO_x (Other pollutants)	NO_x emission values are expressed in gross calorific value GCV.
Sound-power level indoors L_{WA}	§7.17 refers to EN 15036 - 1:2006 Heating boilers - Test regulations for airborne noise emissions from heat generators	
Sound-power level outdoors L_{WA}	EN 15036 - 2:2006 Heating boilers - Test regulations for airborne noise emissions from heat generators	Not considered in EN50465:2015/A1:2019
Seasonal space-heating energy efficiency η_s of boiler space-heaters, boiler combination heaters and cogeneration		Additional elements for measurements and calculations related to the seasonal space-heating energy efficiency of boiler space-heaters, boiler combination heaters and cogeneration space-heaters.

space-heaters		
---------------	--	--

5. ELECTRIC HEAT-PUMP SPACE-HEATERS AND HYBRID HEAT-PUMP SPACE-HEATERS

General conditions	test	EN 14511-2: 2022 <i>Air conditioners, liquid chilling packages and heat-pumps for space-heating and cooling and process chillers, with electrically driven compressors - Part 2: Test conditions</i>	Notes
Standard conditions	rating	Heating: Water & Brine. Tables 7 (LT), 9 (MT) & 10 (HT) and Outdoor air & Exhaust air, Tables 12 (LT), 14 (MT) and 15 (HT) Cooling: Water & Brine. Tables 11 and 16	
		EN 14825-2022 <i>Air conditioners, liquid chilling packages and heat-pumps, with electrically driven compressors, for space-heating and cooling, heat-pumps, with electrically driven compressors, for space-heating – Testing and rating at part-load conditions and calculation of seasonal performance</i>	
Reference conditions for heating $P_{designh}$, T_{biv} , TOL	design	§6.1. reference conditions for space-heating. $P_{designh}$ = +2, -10, -22 °C; T_{biv} = +7, +2, -7 °C; TOL = +2, -7, -15 °C for climates Warmer, Average, Colder	
Part-load conditions for heating	test	§ 6.4 Air-to-water(brine) units Tables 8, 10 and 11 §6.5 DX-to-water(brine) and water(brine)-to-water(brine) units. Tables 12, 14 and 15. The tables give test conditions A to G relating to source (bin) temperatures and – variable or	All heating seasons (A, W,C) and temperature regimes are covered. Note that for brine ground heat exchanger heat-pumps the new regulation uses higher source temperatures (5/2 instead of 0/-3 °C)

	fixed – sink temperature regimes.	<p>The wet-bulb temperature conditions for exhaust air in the standard have to be changed from 20(12) to 20(15).</p> <p>The mean logarithmic temperature difference should be introduced to enable the possible deployment of CO2 as a refrigerant.</p>
Seasonal space-heating energy efficiency $\eta_{s,h}$ and initial determination of seasonal coefficient of performance $SCOP$	<p>§7.2.</p> $\eta_{s,h} = (1/CC) \times SCOP_{on} \Sigma F(i)$ <p>§7.3. $SCOP = Q_H / Q_{HE}$ where Q_H is annual heat demand and Q_{HE} is annual heating energy.</p> <p>§7.4. $Q_H = P_{designh} \times H_{HE}$ where $P_{designh}$ is design heat load in kW and H_{HE} is the equivalent active mode hours.</p> <p>§7.5. With hours (and measured power) for auxiliary and off modes the formula for $SCOP_{on}$ is complete</p>	<p>$\eta_{s,h}$ to be updated as follows:</p> $\eta_{s,h} = (1/CC) \times SCOP_{on} \times (1 - \Sigma F(i))$ <p>The equivalent active mode hours H_{HE} are given in Annex B.</p> <p>The hours for off-mode H_{OFF}, thermostat-off mode H_{TO}, standby mode H_{SB} and crankcase heater mode H_{CK} are given in Annex B2. and B3.</p>
Seasonal coefficient of performance in active mode $SCOP_{on}$	<p>§7.6 and §7.7. $SCOP_{on}$ is derived from capacity P and COP at the standard rating conditions A to F. Missing bin values are determined by interpolation / extrapolation. When P is more than heat demand in a bin, the cycling impact is calculated (parameters CR, Cd). When P is less than the bin heat demands the electric backup ($elbu$) heat is required. In the end, the COP values per bin are summed, weighted for the bin hours per bin.</p>	<p>Annex B.1.3 Heating: Table A.2 with look-up for bin hours per outdoor temperature, needed for calculating $SCOP_{on}$</p>
Reference design conditions for cooling $T_{designc}$	<p>§4.1. Reference conditions for space heating. $T_{designc} = +35$ °C, only one relevant climate.</p>	

Part-load test conditions for cooling	<p>§4.4 Air-to-water(brine) units Tables 4.</p> <p>§4.5 DX-to-water(brine) and water(brine)-to-water(brine) units. Table 5.</p> <p>The tables give test conditions A to D relating to source (bin) temperatures and – variable or fixed – sink temperature regimes.</p>	
Seasonal space-cooling energy efficiency $\eta_{s,c}$ and determination of Seasonal energy-efficiency ratio	<p>§5.2.</p> $\eta_{s,c} = (1/CC) \times SEER_{on} \Sigma F(i)$ <p>§5.3. $SEER = Q_C / Q_{CE}$ where Q_C is annual cooling demand and Q_{CE} is annual cooling energy.</p> <p>§5.4. $Q_H = P_{designc} \times H_{CE}$ where $P_{designc}$ is design cooling load in kW and H_{CE} is the equivalent active mode hours.</p> <p>§5.5. With hours (and measured power) for auxiliary and off modes the formula for $SEER_{on}$ is complete</p>	<p>$\eta_{s,c}$ to be updated as follows:</p> $\eta_{s,c} = (1/CC) \times SEER_{on} \times (1 \square \Sigma F(i))$ <p>The equivalent active mode hours H_{CE} are given in Annex A below 12 kW and in Annex D above 12 kW.</p> <p>The hours for off-mode H_{OFF}, thermostat-off mode H_{TO}, standby mode H_{SB} and crankcase heater mode H_{CK} are given in Annex A2. and A3 below 12 kW and in D2 and D3 above 12 kW.</p>
Seasonal energy-efficiency ratio in active mode $SEER_{on}$	<p>§5.6 and §5.7. $SEER_{on}$ is derived from capacity P and EER at the standard rating conditions A to D. Missing bin values are determined by interpolation/ extrapolation. When cooling output is more than cooling demand in a bin, the cycling impact is calculated (parameters CR, Cd).</p>	<p>Annex A1 below 12 kW and D1 above 12 kW, Tables for bin hours per outdoor temperature, needed for calculating $SEER_{on}$</p>
Separate test method for hybrids, i.e. heat-pumps combined with gas or liquid fuel fired heating boilers.	<p>§8.2 The heat-pump is tested, with fuel boiler attached but not working at standard rating conditions for bin-temperatures higher than $T_{fb,off}$. The fuel boiler is tested according to EN 15502-1 (gas) or EN 304 (liquid fuel). heat output and COP values for</p>	<p>$T_{fb,off}$ (fuel boiler off) corresponds to T_{biv}, i.e. the lowest bin temperature where the heat-pump can supply the heat demand on its own.</p> <p>$T_{hp,on}$ (heat-pump on) corresponds to TOL, i.e. the lowest bin temperature where the heat-pump can still have a contribution to supply the heat demand.</p>

	missing bins are inter/extrapolated, similar as for <i>elbu</i> .	The active mode efficiency of the fuel boiler is η_{son_fuelbu} (considered constant independent of load)
Combined test method for hybrids, i.e. heat pumps combined with gas or liquid fuel fired heating boilers	§8.3 The hybrid unit is tested as a 'black box', measuring electricity and fuel at each of the rated test conditions, using the controls of the unit. Installation is according to EN 14511-3, the boiler according to EN 15502-1 (gas) or EN 304 (liquid fuel). Electricity or fuel consumption values for missing bins are interpolated/extrapolated.	$T_{fb,off}(T_{biv})$ and $T_{hp,on}(TOL)$ are also rated test conditions.
Cycling parameters P_{cyc} , T_{cyc} , C_d , settings for CR	§11.5 and §11.6	
P_{TO} , P_{OFF} , P_{SB} , P_{CK}	§12. Test methods for electric power consumption during off mode, thermostat off mode, standby mode and crankcase heater mode	

6. FUEL HEAT-PUMP HEATERS (ABSORPTION)

General conditions test	prEN 12309-3:2021 Gas-fired sorption appliances for heating and/or cooling with a net heat input not exceeding 70 kW – Test methods	prEN 12309-3:2021 will combine Parts 3, 4 and 5 under development; 2019 version available.
Standard conditions rating	Tables 6 (brine/water), 7 (brine/water, sound power), 8 (air), 10 (air, sound power)	as EN14511-2:2018, but with explicit tables for sound power test
	prEN 12309-6:2021 Gas-fired sorption appliances for heating and/or cooling	

		<i>with a net heat input not exceeding 70 kW – Calculation of seasonal performances</i>	
Reference conditions T_{biv}, TOL	design $P_{designh}$	§5.1. Table 4 reference conditions for space-heating.	as EN 14825
Part-load conditions	test	§5.2.2.1 Air-to-water(brine) units. Tables 5,6,7 (LT). §5.2.2.2 Air-to-water(brine) units. Tables 8,9,10 (MT). §5.2.3.2 water(brine)-to-water(brine) units. Tables 17,18,19 (LT) §5.2.3.3 water(brine)-to-water(brine) units. Tables 20,21,22 (MT)	as EN 14825 gas and electricity consumption per test condition registered and calculated differently but with similar outcome as with electric heat-pump
Seasonal heating efficiency $\eta_{s,h}$ and initial determination of seasonal primary energy ratio SPER	space-energy	§5.2. $SPER = 1 / \{ Prim_{gas} / SFUE + Prim_{elec} / SAEF \}$ FUE = Fuel-utilisation efficiency AEF = Auxiliary energy factor $Prim_{gas}$ = primary energy gas in GCV (=1); $Prim_{elec} = CC$	In principle similar to EN 14825 but there is the problem of two different types of energy sources.
Seasonal coefficient of performance in active mode $SFUE_{on}$		§5.4 Table 29 is the bin-table to facilitate calculation of <i>Seasonal FUE (SFUE)</i>	Similar to EN 14825
NOx emissions		EN 14792:2017 Stationary source emissions. Determination of mass concentration of nitrogen oxides. Standard reference method. Chemiluminescence.	This is a standard reference method (SRM) for the determination of nitrogen oxides (NOx) in flue gases emitted to the atmosphere from ducts and stacks. It is a universal method, used amongst others in medium and larger combustion plants.
Hybrid appliances		<i>EN 12309-7: 2014. Gas-fired sorption appliances for heating and/or cooling with a net heat input not exceeding 70 kW - Part 7: Specific provisions for hybrid appliances</i>	Similar to the methods proposed in EN 14825:2020.

Liquid or gaseous fuel sorption heat pumps Emission of nitrogen oxides NO _x	New European Standard under development within the CEN/TC299 WG2 expert group EN 12309-2:2015. Section 7.3.13 'NO _x Measurements' (CEN/TC299 WG2)	NO _x emission values shall be measured in mg/kWh fuel input and expressed in gross calorific value GCV. No alternative methods to express NO _x in mg/kWh output may be used.
Sound-power level (LWA) of heat-pump space heaters and heat-pump combination heaters	For sound-power level indoor measured and outdoor measured: EN 12102-1:2018 Air conditioners, liquid chilling packages, heat pumps and dehumidifiers with electrically driven compressors for space-heating and cooling - Measurement of airborne noise - Determination of the sound-power	To be used also for liquid or gaseous fuel sorption heat pumps

7. FUEL HEAT-PUMP HEATERS (ENGINE)

Standard conditions	rating	Tables 6 (brine/water), 7 (brine/water, sound power), 8 (air), 10 (air, sound power)	as EN14511-2:2018, but with explicit tables for sound-power test
		EN 16905-5:2017 <i>Gas-fired endothermic engine driven heat pumps — Calculation of seasonal performances</i>	
Reference conditions T_{biv} , TOL	design $P_{designh}$	§5.1. Table 4 reference conditions for space-heating.	as EN 14825
Part-load conditions	test	§5.4.2 Air-to-water(brine) units. Tables 11,12,13 (LT). §5.4.3 Air-to-water(brine) units. Tables 14,15, 16 (MT). §5.5.2 water(brine)-to-water(brine) units. Tables 20,21,22 (LT) §5.5.3 water(brine)-to-water(brine) units. Tables 23,24,25 (MT)	as EN 14825

Seasonal primary energy ratio SPER	<p>§7.1</p> $SPER = 1 / \{ Prim_{gas} / SFUE + Prim_{elec} / SAEF \}$ <p><i>SFUE</i> = Fuel-utilisation efficiency</p> <p><i>AEF</i> = Auxiliary energy factor</p> <p><i>Prim_{gas}</i> = primary energy gas in GCV (=1); <i>Prim_{elec}</i> = CC</p>	as EN 12309-6
Seasonal coefficient of performance in active mode <i>SFUE_{on}</i>	<p>§7.4 Table 29 is the bin-table to facilitate calculation of <i>Seasonal FUE (SFUE)</i></p>	as EN 12309-6
NOx emissions	<p>EN 14792:2017</p> <p>Stationary source emissions. Determination of mass concentration of nitrogen oxides. Standard reference method. Chemiluminescence.</p>	<p>This is a standard reference method (SRM) for the determination of nitrogen oxides (NOx) in flue gases emitted to the atmosphere from ducts and stacks. It is a universal method, used amongst others in medium and larger combustion plants.</p> <p>[To check whether specific NOx measurements are in the EN 16905 series]</p>
Sound-power level (LWA) of heat-pump space-heaters and heat-pump combination heaters	<p>For sound-power level indoor measured and outdoor measured:</p> <p>EN 12102-1:2018 Air conditioners, liquid chilling packages, heat pumps and dehumidifiers with electrically driven compressors for space heating and cooling - Measurement of airborne noise - Determination of the sound power</p>	To be used also for liquid or gaseous fuel sorption heat-pumps

8. COMBINATION HEATERS

<p>Water-heating energy efficiency and references: $\eta_{wh,,}$, Q_{fuel}, Q_{elec}, Q_{cor}, AFC, AEC, $V40$</p>	<p>prEN 13203-2:2021. Gas-fired domestic appliances producing hot water - Part 2: Assessment of energy consumption.</p> <p>§7. Ecodesign Related Products Data ($\eta_{wh,,}$, Q_{fuel}, Q_{elec}, Q_{cor}, AFC, AEC, $V40$)</p> <p>EN 13203-1:2015. Gas fired domestic appliances producing hot water - Part 1: Assessment of performance of hot water deliveries.</p> <p><i>Note: all tests with energy use in summer mode $Q_{gas,p} = Q_{gas,S}$</i></p>
---	---

	<p>prEN 13203-4:2021. Gas-fired domestic appliances producing hot water - Part 4: Assessment of energy consumption of gas combined heat-and-power appliances (mCHP) producing hot water and electricity.</p> <p>§7. Ecodesign Related Products Data (η_{wh}, Q_{fuel}, $E_{electricity,d}$, Q_{cor}, AFC, AED)</p>
	<p>prEN 13203-5:2021. Gas-fired domestic appliances producing hot water - Part 5: Assessment of energy consumption of gas-fired appliances combined with electrical heat pump.</p> <p>§. TBW</p>
	<p>prEN 13203-6:2021. Gas-fired domestic appliances producing hot water - Part 6: Assessment of energy consumption of adsorption and absorption heat pumps.</p> <p>§. TBW</p>
	<p>prEN 13203-7:2021. Gas-fired domestic appliances producing hot water - Part 7: Assessment of energy consumption of combination boilers equipped with a passive flue heat recovery device.</p> <p>§. 6.3.2.2.1 Central heating input</p> <p>During the test of the declared water heating load profile according to EN 13302-2:2021, from 06:00 to 21:30h of the profile reference time and when the boiler is not performing its water heating function, the boiler will continuously operate in central heating mode with a feed temperature of 43 °C and a return temperature of 37 °C.</p>
	<p>EN 303-6:2019. Heating boilers - Part 6: Heating boilers with forced draught burners - Specific requirements for the domestic hot water operation and energy performance of water heaters and combination boilers with atomising oil burners of nominal heat input not exceeding 70 kW</p> <p>§ TBW</p>
	<p>EN 16147:2017/FprA1:2020. Heat-pumps with electrically driven compressors - Testing, performance rating and requirements for marking of domestic hot water units.</p> <p>§7. Performance tests.</p> <p>annex A. Load (tapping) profiles</p>
	<p>EN 50440:2015+A1:2020 Efficiency of domestic electrical storage water heaters and testing methods</p>
	<p>EN 12897:2016+A1:2020. Water supply. Specification for indirectly heated unvented (closed) storage water heaters.</p>

Note that the two latter standards are not strictly for combination heaters (but for dedicated water heaters) but are shown here for lack of a better alternative.

9. SHOWER WATER HEAT RECOVERY DEVICES

Shower water heat recovery device efficiency (%)	<p>NEN 7120:2011/C2:2011 NTA8800:2020, Bijlage U CSTB Protocol RECADO 2015</p> <p>All three test standards may be accepted as method to determine shower heat recovery device efficiency, as long as the test conditions in ANNEX VII, point 4 are met. The efficiency to use in calculations should be determined using shower water flow rates equal or larger than the water flow rates shown in the table (combination of devices to achieve sufficient capacity is allowed)</p>
--	--

10. SOLAR DEVICES AND PACKAGES INCLUDING SOLAR DEVICES

Measurement of solar collectors	ISO 9806:2017	Tests produces the input-parameters for the GTY calculation below
Storage tank standing losses (used in tank factor f)	<p>FprEN 15332:2019 Clause 5.3 EN 12897:2016+A1:2020 Clause 6.2.2 Annex B EN 12977-3:2018 Annex F.2</p>	When determining standing losses using EN 12897 all relevant volumes, for both/either primary side and domestic side should be filled and heated to required storage temperatures, in a similar way to how the tank would be used in real-life. See EN 15332 for instructions.
Gross thermal yield (GTY) of solar devices the solar collectors of which are tested separately	<p>ScenoCalc v6.1, using inputs from ISO 9806:2017</p> <p>Use prEN 12975:2021, Annex B, Clause B.2.1 for calculation of GTY, Clause B.1.2 and B.3 for the climate reference conditions.</p>	The calculation of GTY shall be climate specific (Helsinki/Stockholm, Strasbourg/Würzburg, and/or Athens) and consider orientation and inclination as indicated in Annex VII. The GTY calculated is the summation of the gross thermal yield (GTY) and gross electric yield (GEY) for the average of collector mean temperatures of 25°C and 50°C
Water-heating demand $Q_{wh,sol}$	Annex III, point 10	$Q_{wh,sol} = Q_{ref} * 366 * 0.6 * (Q_{ref} + 1.09)$
Correction factor $f_{profile}$	Annex III, point 10	
Correction factor a , b , c and d , for water heating		
Correction factor a , b		

and c , for space heating		
Solar device efficiency for water heating $\eta_{sol,wh,clim}$		
Solar device efficiency for space heating $\eta_{sol,sh,clim}$		
Solar-assisted combination heater water heating energy efficiency η_{wh+sol}		
Solar-assisted heater space-heating energy efficiency η_{sh+sol}		
Tank factor f_{tank}		

11. ACCURACY OF MONITORING

1. The monitoring accuracy can be measured by comparing the monitored values to the values measured with laboratory equipment during tests performed to establish the compliance of the product with the minimum energy-efficiency requirements.
2. The monitoring accuracy can also be measured using standardised accuracy proofs from EN standards indicated in Table 1 and showing that the corresponding accuracy level(s) imply that the requirements for accuracy of monitoring of this regulation are met.

Table 1
Accuracy of monitoring

Gas metering accuracy	EN 14236:2018	Ultrasonic domestic gas meters
	EN 1359:2017	Diaphragm gas meters
Electricity metering accuracy-acceptance inspection	EN 62058-11:2010	Acceptance inspection – Part 11: General acceptance inspection methods
	EN 62058-21:2010	Part 21: Particular requirements for electromechanical meters
	EN 62058-31:2010	Part 31: Particular requirements for static meters
	EN 62058-32-1:2012	Part 32-1: Durability – Testing ... by applying elevated temperatures
Heat metering	EN1434-1:2015	Part 1: General requirements

ANNEX V

Product compliance verification by market surveillance authorities

1. INTRODUCTION

The verification tolerances set out in this Annex relate only to the verification conducted by Member State authorities of the declared values and shall not be used by the manufacturer, importer or authorised representative as an allowed tolerance to: (i) determine the values in the technical documentation or in interpreting these values with a view to achieving compliance; or (ii) communicate better performance by any means.

2. PROCEDURE

As part of verifying the compliance of a product model with the requirements laid down in this Regulation, for the requirements referred to in this Annex, the authorities of the Member States shall apply the procedure set out in the points below.

- (a) The Member State authorities shall verify one single unit of the model.
- (b) The model will be considered to comply with the applicable requirements if:
 - (i) the values given in the technical documentation pursuant to point 2 of Annex IV to Directive 2009/125/EC (declared values), and, where applicable, the values used to calculate these values, are not more favourable for the manufacturer or importer than the results of the corresponding measurements carried out pursuant to point (g) thereof; and
 - (ii) the declared values meet all requirements laid down in this Regulation, and any required product information published by the manufacturer or importer does not contain values that are more favourable for the manufacturer or importer than the declared values; and
 - (iii) when the Member State authorities test the unit of the model, the determined values (the values of the relevant parameters as measured in testing and the values calculated from these measurements) comply with the respective verification tolerances as given in Table 1.
- (c) If the results referred to in point (b) (i) or (ii) are not achieved, the model and all other equivalent models shall be considered not to comply with this Regulation. The Member State authorities shall provide all relevant information to the authorities of the other Member States and to the Commission without delay after a decision is taken on the non-compliance of the model.
- (d) If the result referred to in point (b) (iii) is not achieved, the Member State authorities shall select three additional units of the same model for testing. As an alternative, the three additional units selected may be of one or more different equivalent models.
- (e) The model shall be considered to comply with the applicable requirements if, for these three units, the arithmetical mean of the determined values complies with the respective verification tolerances given in Table 1. In addition, for heat-pumps and hybrid heat-pumps tested with the compensation method, there shall be no cycling on/off for any of the test points for at least two of the units.
- (f) If the result referred to in point (e) is not achieved, the model and all other equivalent models shall be considered not to comply with this Regulation.

- (g) The Member State authorities shall provide all relevant information to the authorities of the other Member States and to the Commission without delay after a decision being taken on the non-compliance of the model according to points (c) and (f).

The Member State authorities shall use the measurement and calculation methods set out in Annex III.

Given the weight and size limitations for the transportation of heaters with a standard-rated heat output of 400 kW or more, Member States authorities may decide to undertake the verification procedure at the premises of manufacturers, authorised representatives or importers before the products are placed on the market or put into service. The Member State authority can do this verification using its own testing equipment.

If factory acceptance tests are planned for such heaters, which will test parameters laid down in Annex I of this Regulation, the Member State authorities may decide to use witnessed testing during these factory acceptance tests to gather test results which can be used to verify compliance of the heater under investigation. The authorities may request a manufacturer, authorised representative or importer to disclose information on any planned factory acceptance tests relevant for witnessed testing.

In the cases mentioned in the two paragraphs above, the Member States authorities only need to verify one single unit of the model. If the result referred to in point b (iii) is not achieved, the model and all equivalent models shall be considered not to comply with this regulation.

3. VERIFICATION TOLERANCES

The Member State authorities shall only apply the verification tolerances that are set out in Table 1 and shall only use the procedure described in Section 2 for the requirements referred to in this Annex. No other tolerances, such as those set out in harmonised standards or in any other measurement method, may be applied.

Table 1
Verification tolerances

Parameters	Verification tolerances
Seasonal space-heating energy efficiency of fuel and electric boilers, η_s	The determined value shall not be lower than the declared value by more than 4% (relative tolerance).
Seasonal space-heating energy efficiency of fuel boiler heater with a standard-rated heat output of more than 70 kW and less or equal to 1 MW, η_1 and η_4	The determined value shall not be lower than the declared value by more than 4% (relative tolerance).
Seasonal space-heating energy efficiency of cogeneration and heat-pump space-heaters, η_s	The determined value shall not be lower than the declared value by more than 8% (relative tolerance).
Water-heating energy efficiency, η_{wh}	The determined value shall not be lower than the declared value by more than 8% (relative tolerance).
Declared load profile	The measured useful energy content should not be lower than 95% of the value of Q_{ref} for the declared load profile.

Sound-power level, L_{WA}	The determined value shall not exceed the declared value by more than 2 dB(A).
Seasonal space-cooling energy efficiency of reversible space-heaters, $\eta_{s,c}$	The determined value shall not be lower than the declared value by more than 8% (relative tolerance)).
Emissions of nitrogen oxides	The determined value shall not exceed the declared value by more than 20%.
Accuracy of self-monitoring	The tolerance for fuel/electricity consumption and heat/electricity delivered shall be not more than what is indicated in Annex II, Section 7.5.
Heating and cooling output of heat-pump heater, hybrid heat-pump heater and fuel heat-pump, measured on the liquid side	The tolerance is $(1 + 20 / \Delta\theta) \%$ of the heating or cooling output where $\Delta\theta$ is the water temperature difference on the indoor side water heat exchanger
EER, COP, FUEc and FUE of heat-pump heater, hybrid heat-pump heater and fuel heat-pump	The tolerance is $(2 + 20 / \Delta\theta) \%$ of the EER, COP, FUEc or FUE, where $\Delta\theta$ is the water temperature difference on the indoor side water heat exchanger
Electric power input for off, thermostat-off, standby and crankcase heater modes of heat-pump heater and hybrid heat-pump heater	The tolerance is <ul style="list-style-type: none"> • 0,3 W up to 10 W; • 3 % of the measured value for powers greater than 10 W
Self-measurement	For the measurement of space heating energy output, the tolerance (expressed in %) shall be $\pm 5 + \frac{50}{\Delta\theta}$, where $\Delta\theta$ is the temperature difference between the inlet and outlet of the water heat exchanger. For the assessment of electricity and fuel consumption, and electrical energy output of cogeneration heaters, a tolerance of $\pm 10 \%$ shall apply. Tolerances related to self-measurement shall be verified against performance measurements conducted in laboratory tests specifically related to evaluate space heating energy efficiency in average climate conditions. Values may be derived from the measurement of relevant technical parameters and/or calculation, as long as the values are within the tolerance.

ANNEX VI

Benchmarks

This section gives benchmarks for the purpose of public procurement according to Directive (EU) 2023/1791 for products that are not in the scope of the [Energy labelling regulation for space-heaters]:

- (a) Benchmarks for seasonal space-heating energy efficiency of heaters are indicated in Table 1.

Table 1

Benchmarks for seasonal space-heating energy efficiency

Space-heater type	seasonal space-heating energy-efficiency
Electric boiler heater	51 %
Heat-pump heater, Hybrid heat-pump heater, Cogeneration heater, low-temperature heating application	175 %
Heat-pump heater, Hybrid heat-pump heater, Cogeneration heater, medium-temperature heating application	145 %

- (b) Benchmarks for water heating energy efficiency of combination heaters are indicated in Table 2.

Table 2

Benchmarks for water heating energy efficiency

Combination heater type	Declared load profile		
	S	M	L-4XL
	Water heating energy efficiency η_{wh}, in %		
All	90	120	120

The benchmarks specified in points (1) and (2) do not imply that a combination of these values is achievable for a single heater.

ANNEX VII

Sampling rates for conformity assessment procedures of heaters

1. This section sets out the specifications of the conformity assessment procedure modules identified in Article 4(2).
2. The conformity assessment of the seasonal space-heating energy efficiency, the seasonal space-cooling energy efficiency, the sound-power level (indoor, and outdoor where relevant) and of the self-monitoring equipment accuracy shall be conducted **by testing a single model per type**.
3. A type is defined as all the models that share all the following characteristics:
 - (a) For boiler heaters:
 - (1) either a combination heater or space-heater;
 - (2) B1 boiler heater;
 - (3) the same capacity;
 - (4) the same seasonal space-heating energy efficiency, and
 - (5) the same fuel type (i.e., gaseous or liquid fuel).
 - (b) For cogeneration heaters:
 - (1) combination heater or space-heater;
 - (2) the same capacity;
 - (3) the same seasonal space-heating energy efficiency, and
 - (4) the same technology of combined heat and power.
 - (c) For heat-pump heaters and hybrid heat-pump heaters:
 - (1) combination heater or space-heater;
 - (2) the same heat source (outdoor air to water, ventilation exhaust air to water, ground heat exchanger, ground direct exchange);
 - (3) availability of the cooling function (reversibility);
 - (4) the same refrigerant type and mass;
 - (5) the same condenser;
 - (6) the same compressor;
 - (7) the same evaporator;
 - (8) the same defrost technology, and
 - (9) the same expansion valve technology;
4. The minimum sampling sized for EU type examination, according to module B of Annex II of Decision 768/2008 shall be carried out on a model representative of the type as defined in point (3). The minimum sampling rate is one type every five types.
5. The minimum sampling sized of the production to the type shall be one representative model for a given number of types as defined in point (3). The minimum sampling rates of the production to the type and associated time periods, shall be as follows:

- (1) for the module C2 – one out of ten types, every year;
- (2) for the module D – one out of five types, every three years.

ANNEX VIII

Amendment to Regulation (EU) 813/2013

1. In Annex I, after the subtitle “Definitions related to water heating in combination heaters”, the following definition is inserted as definition (55):

(55) ‘out of the box-mode’ is the standard operating condition, setting or mode set by the manufacturer at factory level, to be active immediately after the appliance installation, suitable for normal use by the end-user according to the water tapping pattern for which the product has been designed and placed on the market. Any change to a different operating condition, setting or mode, if applicable, shall be the result of an intentional intervention by the end-user, and cannot be automatically modified by combination heater at any time, except for smart control function adapting the water heating process to individual usage conditions with the aim of reducing energy consumption.’

2. Annex III shall be amended as follows:

- (a) In point 2 on “General conditions for measurements and calculations”, the following text, is added in letter (c):

‘A default or reference nitrogen content in the fuel of 140 mg/kg shall be applied. Where another nitrogen content is measured, the following correction equation shall apply:

$$\text{NOx(EN 267)[mg/kWh]} = \text{NOxref[mg/kWh]} - (\text{Nmeas} - \text{Nref}) \times 0,2$$

Where:

NOx(EN 267) is the value of NOx corrected to the reference conditions of nitrogen of the fuel oil chosen at 140 mg/kg;

EN 267 means CEN standard EN 267:2009+A1:2011;

NOxref is the measured value of NOx according to paragraph B.2 in standard EN 267:2009+A1:2011;

Nmeas is the value of the nitrogen content of the fuel oil measured in mg/kg;

Nref is the default or reference nitrogen content, which equals 140 mg/kg.

The value of NOx(EN 267) is the one to be compared to the maximum NOx emission requirements values set in section 4 of Annex II to this Regulation.’.

- (b) in point 5 on “Water heating energy efficiency of combination heaters”, the text in letter (a) is replaced by the following:

‘water-heating tests shall be performed in the ‘out of the box-mode’; measurements shall be carried out using the load profiles in Table 7;’.