



17 August 2026

(26-5764)

Page: 1/2

Committee on Technical Barriers to Trade

Original: English

NOTIFICATION

The following notification is being circulated in accordance with Article 10.6

1.	Notifying Member: <u>THE SEPARATE CUSTOMS TERRITORY OF TAIWAN, PENGHU, KINMEN AND MATSU</u> If applicable, name of local government involved (Articles 3.2 and 7.2):
2.	Agency responsible: Bureau of Standards, Metrology and Inspection (BSMI) Ministry of Economic Affairs
3.	Notified under Article 2.9.2 [X], 2.10.1 [], 5.6.2 [X], 5.7.1 [], 3.2 [], 7.2 [], Other:
4.	Products covered (HS codes or national tariff lines. ICS numbers may be provided in addition, where applicable): Static converters (HS code(s): 850440); Lithium-ion accumulators (excl. spent) (HS code(s): 850760); Electric accumulators (excl. spent, and lead-acid, nickel-cadmium, nickel-metal hydride and lithium-ion accumulators) (HS code(s): 850780)
5.	Details of notified document(s) (title, number of pages and languages, means of access): Proposal for Amendments to the Legal Inspection Requirements for Energy Storage Systems Including Stationary Lithium Energy Storage Systems; (8 page(s), in English), (7 page(s), in Chinese) Link to notified document(s) and/or contact details for agency or authority which can provide copies upon request: https://members.wto.org/crnattachments/2026/TBT/TPKM/26_04265_00_e.pdf https://members.wto.org/crnattachments/2026/TBT/TPKM/26_04265_00_x.pdf WTO TBT Enquiry Point, Email: tbtenq@bsmi.gov.tw
6.	Description of content: To support the energy transition policy and ensure the safe deployment of large-scale energy storage systems, the BSMI proposes to expand the scope of mandatory inspection for stationary lithium energy storage systems and secondary lithium batteries intended for use in such systems. Products with a rated energy capacity of 100 kWh or below are already subject to mandatory inspection. Under this proposal, the maximum rated energy capacity covered by mandatory inspection requirements would be increased from 100 kWh to 360 kWh. In addition, the technical requirements for stationary lithium energy storage systems would be revised to align the cyber security and grid interconnection requirements with newly published CNS standards. Secondary lithium battery packs for road vehicle propulsion would remain subject to the existing mandatory inspection requirements, and their inspection scope and technical requirements would not be changed under this proposal.
7.	Objective and rationale, including the nature of urgent problems where applicable: Protection of human health or safety; Protection of the environment

8. Relevant documents:

Government Gazette, Vol. 032, No. 148, dated 12 August 2026.

(https://gazette.nat.gov.tw/egFront/e_detail.do?metaid=167631)

The Commodity Inspection Act.

Relevant notifications:

- [G/TBT/N/TPKM/564/Add.1](#)
- [G/TBT/N/TPKM/566/Add.1](#)
- [G/TBT/N/TPKM/572/Add.1](#)

9. Proposed date of adoption: To be determined

Proposed date of entry into force: 1 July 2028

10. Provision of comments

Final date for comments: 16 October 2026

[X] 60 days from notification

Contact details of agency or authority designated to handle comments regarding the notification:

WTO TBT Enquiry Point
 Bureau of Standards, Metrology and Inspection
 Ministry of Economic Affairs
 No. 4, Sec. 1, Jinan Rd., Zhongzheng Dist.
 Taipei City 100, Taiwan
 Tel: +(886-2) 23431700#1566
 Fax: +(886-2) 23431804
 Email: tbtenq@bsmi.gov.tw